

**RDR PROCESS WATER
&
VALUE ENGINEERING ITEMS**


June 5, 2008

GDE Meeting-ILC CFS Workshop in Dubna, Russia

Emil Huedem, Fermilab


- RDR process water-Timeline
- Heat Load (RDR & Post RDR)
- Delta T
- Value Engineering items

RDR Process Water (Timeline)



- Nov-Dec 6 2006 Concept and cost Process Water (Stop Dec 06 2006)
- Aug 23 2007 EDR Kick Off Meeting
(task: Get as much info and evaluate to get high delta T)
- Oct-2007 GDE, some Updates on ML heat table
- Nov 27 2007 Value Engineering (VE) session
(Post RDR Delta T evaluate -more on this later in the slide)
- Dec 4 2007 Marc list from VE list *(more on this later in the slide)*
interface with HLRF people re: delta T, heat load, non-cfs VE items
- Dec 18 2007 Stopped work
minimal interface with Atsushi, Masami, Peter..


RDR Process Water (Timeline)



About RDR

- Criteria and heat loads were incomplete. Snapshot in time
- Cooling infrastructure in RDR was conceptual, and very little on paper.
- Cost was generated for shaft 7 based on info at that time
- Not a unified criteria??
- LCW part was immature.
- Instead of criteria,..Various Cost reduction discussion,



Basic Design Concept in RDR



Water Plant at Shaft 7

Surface Plant Locations* used in RDR

* (follows major shaft locations)



Total Heat Load RDR Nov 2006

THERMAL LOAD USED (In MW) (...and still changing....)

Updated Nov 27, 2006 CES

Area System	LCW	Chilled Water	Total	Sources
SOURCES e-	2.9	1.4	4.3	Aug 21 (Clay) 4.36;3.72;2.53 MW for LCW, 1.53;1.31;0.89 MW for Air- Numbers are PSTD (peak simultaneous thermal demand);INPTC (installed nameplate thermal capacity) ;ATL (Average thermal demand) Nov 21 2006 Updated total loads per Clay's email dated 11/20/06
SOURCES e+	17.5	5.3	22.8	
DR e-	8.8	0.9	9.8	Oct 16 2006 Emails Andy Wolski (Load to CHW are for equipment load to air in Alcoves only and these are 560KW from RF, and 364KW from Magnet Power Supplies per ring). The other load to air are 197KW from aircooled magnets , and 700 KW from radiation are not listed here and assume dissipated to tunnel wall. Load to LCW includes load to air to tunnel that will be transferred to process water via fancoils to maintain 104F. Nov 27 2006 No updates from AWolski. Use old total loads, but with two less shaft for distribution
DR e+	8.8	0.9	9.8	
RTML	9.3	1.3	10.6	May 24 (Jerry, PT) preliminary ~7 MW per RTML Oct 27 2006 Updated numbers per PTreduction (email oct 25), JS elect table & PBellomo Sep 15 table, but ignored the added 1 watt per meter to air for transr line (ignore in tabulation for now), and ignored the added 10KW watercooled (from 100 m length) in the vertical arc (assume near shaft 2 and 3 each) Nov 27 2006 No Updates. use old loads
MAIN LINAC	56.0	21.1	77.1	Jun 1 (Shigeki et. al.) spreadsheet per RF x 624 RF Sep 18 Updated to move all charging supply to LCW, updated other heat load to air. Oct 25 2006 Marc andKeith Pushback on Load, 40% reduction in racks, remove technical components load to air, remove chw fancoils, used R Casell numbers for charging supply Nov 27 2006 ML 9-8-9 and pushback updated heat table from C.Adolphsen and K.Jobe, Total RF used is 560. Load to air is added back. Used 100% LCW. Dirty water usage still under discussion.
BDS	10.3	1	11.3	Sep 15 (Bellomo) Cable Loss to Air (1.07MW), PS loss to Air (0.982MW); PS loss to water (1.41MW); Magnet Power 14.872 MW (assume 5% magnet is aircooled). Except for PS loss to air (which will be chilled water), all other loads will be to LCW (will use process water fancoil instead of chilled water) Oct 19 2006 (Adjust LCW load, minor Cable loss to air absorb by wall) Nov 14 2006 Adjustment for One IR w Andrei, new loads scaled based on Sep 15 PBellomo list
DUMPS	36	0	36	Aug 15 (Andrei) -reconfigure such that one or two plant sized for(2) 18MW serves (6) 18MW dumps, only (2) are active at any time. Aug 25 (Fred), adjust shaft locations, (Keith) surface distribution from one plant to various drilled shaft, excluding LCW skid Nov 27 2006 . No Changes. Used old loads

149.58

31.971

182

IR = None

MLRF Heat Load – RDR Nov 2006

Nov 27b 2006

WATER AND AIR HEAT LOAD (all LCW) and 9-8-9 ML

MAIN LINAC - ELECTRON & POSITRON

Components	Quantity Per 36m	Location	To Low Conductivity Water							to Chilled Water	Keith Jobe load to air Nov 22 06		Max Space Temp (C)
			Heat Load to Water (KW)	Supply Temp (variation) (C)	Delta Temperature (C delta)	Water Flow (l/min)	Maximum Allowable Pressure (Bar)	Typical (water) pressure drop Bar	Acceptable Temp Variation delta C		Heat Load to Water (KW)	Power fraction to Tunnel Air (0-1)	
Non-RF Components													
LCW Skid Pump 1 per 4 rf -Motor/Feeder Loss	0.25	Service Tunnel	0	N/A	N/A		N/A	N/A	None	0	1.00	0.60	<div style="border: 2px solid red; padding: 5px; color: red; font-weight: bold;"> Shigeki, Chris A., Ray L, R. Cassel, Clay C., Keith J, HLRF Meeting Notes/emails, </div> <p>based on (1) 30 HP per 4 RF from Clay Table Email Clay's Email Nov 22 2006 (2) 1.5 HP per RF (Table 4 Ashrae Chap 28) placed based on (1) 5 HP per 4 rf (table4 Ashrae Chap 28)</p> <p>* Clay - 14 W per sq m</p> <p>* Clay email 3-14-06 typical 112.Kva oil xfmr *</p> <p>* Clay email 3-14-06 typical 112.Kva oil xfmr Keith J</p>
*2R Loss and Motor Loss (misc)	1	Service Tunnel	0	N/A	N/A		N/A	N/A	None	0	1.00	12.01	
Fancoils (5 ton Chilled Water) 1.5 Hp	2	Service Tunnel	0	N/A	N/A		N/A	N/A	None	0	1.00	0.20	
Rack Water Skid	0.25	Service Tunnel	0	N/A	N/A		N/A	N/A	None	0	1.00	1.65	
Lighting Heat Dissipation -1.3W/sf		Service Tunnel	0	N/A	N/A		N/A	N/A	None	0	1.00	1.65	
Lighting Heat Dissipation -1.3W/sf		Accelerator Tunnel	0	N/A	N/A		N/A	N/A	None	0			
People Heat Dissipation 500btuh each	0	Accelerator Tunnel	0	N/A	N/A		N/A	N/A	None	0			
People Heat Dissipation 500btuh each	2	Service Tunnel	0	N/A	N/A		N/A	N/A	None	0			
AC Pwr Transformer 34.5-48 kV	0.25	Service Tunnel	1.50	N/A	N/A		N/A	N/A	None	0	0.25	0.50	
Emerg. AC Pwr Transformer 34.5-48 kV		Service Tunnel	0	N/A	N/A		N/A	N/A	None	0	1.00	1.00	
RF Components													
RF Charging Supply 34.5 Kv AC-8KV DC	1/36 m	Service Tunnel	2.8	40	40	1.17	18	8	10	0	0.3	1.2	<div style="border: 1px solid black; padding: 5px;"> 85 F (a) * C.Jensen email 2-27-06 183 kVa 0.84pf oil ps xfmr **Shigeki Apr 18 2006 ** Clay 5-25-06 LLRF meeting ** Sep 18 move all to LCW per Marc Ross ** Move load to Dirty Water per RCassell Oct 20 2006, **Nov 22 2006 Keith Jobe Wag on load to Air**Nov 27 2006 C. Adolphsen Email ** Move load to Dirty Water per Rcassell Oct 20 2006 LCW for now **Nov 22 2006 Keith Jobe wag on load to air **Chris Jensen Post meeting notes 11 16 06 **Nov 27 2006 C. adolphsen Email * Shigeki Fukuda Email 3-1-06 **Shigeki Apr 18 2006**Nov 22 2006 Keith Jobe wag on load to air** 11-27-06 C. Adolphsen Email **12-1-06 Email from Chris Jensen **Shigeki Apr 18 2006** Nov 22 2006 Keith Jobe wag on load to air**11-27-06 C.Adolphsen Email **Shigeki Apr 18 2006** Marc& Keith -remove load to air/chilled - transfer all load to water**Nov 22 2006 Keith Jobe wag on load to air**11-27-06 C. adolphsen Email * Shigeki Fukuda Email 4-05-06 **Nov 22 2006 Keith Jobe wag on load to air** 11-27-06 C. Adolphsen Email * Shigeki Fukuda Email 3-1-06 **Nov 22 2006 Keith Jobe wag on load to air** 11-27-06 C. Adolphsen Email * Shigeki Fukuda Email 3-1-06** Keith Jobe added stability Oct 20 2006 * * HLRF 11/16 /06 meeting** 11-27-06 C. Adolphsen Email * Shigeki Fukuda Email 3-1-06**11-27-06 C. Adolphsen Email * Shigeki Fukuda Email 3-30-06 **Shigeki Apr 18 2006 (chilled water) ***Rlarsen email** RayLarsen Email 9-15-06 except reduced by 40% per Marc * Ray HLRF Meeting 11/16/06**11-27-06 C. Adolphsen Email **Shigeki Email Apr 28 2006**HLRF 11/16/06 meeting update from 24.3 to 29.8 KW** 11-27-06 C. Adolphsen Email * Shigeki Fukuda Email 3-30-06** Keith Jobe added stability Oct 20 2006** HLRF 11/16/06 meeting from 4 KW to 5 KW**11-27-06 C. Adolphsen Email (a) HLRF meeting Nov 16 2006 </div>
Switching power supply 4kv 50kW	1/36 m		4.5	35	13.6	7.6	13	8	10	0	0.4	3.0	
Modulator	1/36 m	Service Tunnel	4.5				28.82			0	0.4	3.0	
Pulse Transformer	1/36 m	Service Tunnel	0.7							0	0.3	0.3	
Klystron Socket Tank / Gun	1/36 m	Service Tunnel	0.8							0	0.2	0.2	
Klystron Focusing Coil (Solenoid)	1/36 m	Service Tunnel	3.6							0	0.1	0.4	
Klystron Collector	1/36 m	Service Tunnel	45.8	*35>				2		0			
Klystron Body	1/36 m	Service Tunnel	0.0	*35>				5	+ - 2.5 0	0	0.0	1.4	
Klystron Windows	1/36 m	Service Tunnel	0.0	*35>				1		0			
Relay Racks (Instrument Racks)	1/36 m	Service Tunnel	0.0	N/A	N/A		N/A	N/A	None	11.5	-0.2	-1.5	
Circulators, Attenuators & Dummy Load	1/36 m	Accelerator Tunnel	32.3						+ - 2.5 0	0	0.1	1.7	
Waveguide	1/36 m	Accelerator Tunnel	3.5						+ - 2.5 0	0	0.1	0.4	
Subtotal RF unit Only													
Total RF			100							11.5		26.1	

Total Heat load to Chilled water (per R)	37.6 KW	cooled by chilled water
Total Heat load to LCW (per RF)	100.0 KW	cooled by low conductivity water

E Huedem, June 5 2008

POST-RDR Heat Table

- Heat Table improvement! Oct 2007, but still incomplete

Oct 31 2007

WATER AND AIR HEAT LOAD (all LCW) and 9-8-9 ML

MAIN LINAC - ELECTRON & POSITRON														
Components	Quantity Per 36m	Loc	Max Spac e Temp (C)	Max Spac e Temp (C)	Max Spac e Temp (C)	Max Spac e Temp (C)	Max Spac e Temp (C)	Max Spac e Temp (C)	Max Spac e Temp (C)	Max Spac e Temp (C)	Max Spac e Temp (C)	Max Spac e Temp (C)	Max Spac e Temp (C)	Max Spac e Temp (C)
Non-RF Components	Quantity Per 36m	Loc	Max Spac e Temp (C)	Max Spac e Temp (C)	Max Spac e Temp (C)	Max Spac e Temp (C)	Max Spac e Temp (C)	Max Spac e Temp (C)	Max Spac e Temp (C)	Max Spac e Temp (C)	Max Spac e Temp (C)	Max Spac e Temp (C)	Max Spac e Temp (C)	Max Spac e Temp (C)
AC Pwr Transformer 34.5-48 kV	0.25	Service Tunnel	1.50	35										
RF Components														
RF Charging Supply 34.5 Kv AC-8kV DC	1/36	Jensen	2.8	40	40	1.17	18	5	10	0	0.3	1.2		
Switching power supply 4kV 50kW	1/36 m	Service Tunnel	4.5	35	8.50	7.6	18	5	10	0	0.4	3.0		
Modulator	1/36 m	Service Tunnel	4.5	35	3.23	20	10	5	n/a	0	0.4	3.0		
Pulse Transformer	1/36 m	Service Tunnel	0.7	60	35	0.50	20	1	n/a	0	0.3	0.3		
Klystron Socket Tank / Gun	1/36 m	Service Tunnel	0.8	60	35	1.15	10	15	1	n/a	0	0.2	0.2	
Klystron Focusing Coil (Solenoid)	1/36 m	Service Tunnel	5.5	80	55	8	10	15	1	n/a	0	0.1	0.4	
Klystron Collector	1/36 m	Service Tunnel	45.8	87	38 (inlet temp 25 to 63)	18	37	15	0.3	n/a	0	0.0	1.4	85 F (a)
Klystron Body & Windows	1/36 m	Service Tunnel	4.2	40	25 to 40C	6	10	15	4.5	+- 2.5 C	0			
Relay Racks (Instrument Racks)	1/36 m	Service Tunnel	0	N/A	N/A	N/A	N/A	N/A	N/A	None	11.5	-0.2	-1.5	
Attenuators	2/36 m	Service Tunnel	0	N/A	N/A	N/A	N/A	N/A	N/A	None			0.0	
Waveguide (in service tunnel)	1/36 m	Service Tunnel	0										1.166	
Waveguide (in penetration)	1/36 m	Penetration	0.075											
Waveguide (in beam tunnel)	1/36 m	Beam Tunnel	0.0							+- 2.5 C	0		5.0	
Circulators With loads (isolator)	26/36 m	Beam Tunnel	2.49	35	0.45 per load	3 per load				+- 2.5 C	0		0.0	
Loads	24/36 m	Beam Tunnel	30.05	35	2.25 per load	8 per load				+- 2.5 C			0.0	
Subtotal RF unit Only			102.0											
Total RF			103.5								11.5		21.4	

Worked with Shigeki, Chris N., Mike N., Keith J., Jensen, Cassell, Clay

Shigeki (check min Flow?)

??

Cassell

Jensen

Shigeki

NOTE : Loads, Circulators and Klystron Body Supply Temperature is critical (should have very slow supply temp variat

Total Heat load to Air/Chilled water in service tunnel (per RF)	32.9 KW
Total Heat load to LCW (per RF)	103.5 KW
Total Heat load to air in beam tunnel (ignore rock contribution for now)	5.9 KW

Chris and Keith?

Chris Nantista

Loads Increasing

Beam Tunnel Temperature?

E Huedem, June 5 2008


POST RDR

	Heat Load KW per RF		
	RDR	Post RDR <u>as of</u> Dec 07	Post RDR <u>after</u> Dec 07
Service Tunnel (ML RF)			
to water	100	104	
to air	26	21.4	
racks	11.5	11.5	
beam tunnel (ML RF)			
to water	included	included	
to air (wvguide)	0	5.9	
Load to air, servc tunnel, w /m	~ 684		
Servc tunnel temp F	85	104	> 104???
DR tunnel temperature F	104	85 (cooler LCW)	
Metrology reqmnt (GDE Oct 2007)		< 90F	
Air Stability		+ - 0.1 C	
Water Supply stability		+ - 0.2 C	

POST RDR High DELTA-T Evaluation

In RDR there's incomplete component criteria to evaluate the delta T.

Used **20F** delta average for Shaft 7 plant.




POST RDR

Post RDR- High Delta T Evaluation

MAIN LINAC RF WATER SYSTEM (based on incomplete heat table dated Oct 31 2007), excluding Transformer

8 liter /min per load flow

e. huedem 11/15/2007



POST RDR

Post RDR- High Delta T Evaluation

MAIN LINAC RF WATER SYSTEM (based on incomplete heat table dated Oct 31 2007), excluding Transformer


e. huedem 11/15/2007

4 liter /min per load flow

1 RF

Assume 3 psi pressure drop (To be Confirmed)

-73 PSI Press Drop



25 delta T F system

POST RDR

Post RDR- High Delta T Evaluation

MAIN LINAC RE WATER SYSTEM (based on incomplete heat table dated Oct 31 2007), excluding Transformer


3 liter /min per load flow

e. huedem 11/15/2007

1 RF

Assume 3 psi pressure drop (To be Confirmed)

-73 PSI Press Drop




POST RDR

Post RDR- High Delta T Evaluation

MAIN LINAC 2RF WATER SYSTEM (based on incomplete heat table dated Oct 31 2007), excluding Transformer
 8 liter /min per load flow

e. huedem 11/15/2007

8 liter per min per load




POST RDR

Post RDR- High Delta T Evaluation

MAIN LINAC 2RF WATER SYSTEM (based on incomplete heat table dated Oct 31 2007), excluding Transformer
 3 liter /min per load flow

e. huedem 11/15/2007

3 liter per min per load



Post RDR- High Delta T Evaluation

Nov 2007, being pursued this possibility of low-flow, high delta T Load with Chris N, Shigeki & Mike N and their vendor...as well as finding the rest of the info such as the delta P ...

-----Original Message-----

From: Emil Huedem [mailto:huedem@fnal.gov]
Sent: Tuesday, November 06, 2007 9:25 AM
To: Nantista, Christopher D.
Subject: Re: Load & circulator

Chris,

When you obtain this info, can you check if the load/circulator can have lower flow -high delta T?

we're hoping to push the first 95F water into the load/circulator and the outlet of that goes to the rest such as Collector.

The collector from Shigeki has only 37 l/min flow.

The total load/circulator you noted has about 11 l/min flow x 24 (or 26) = a lot more flow than the collector, which will dilute the rest of the high delta T

Thanks

Emil

Post RDR- High Delta T Evaluation

From: Emil Huedem [mailto:huedem@fnal.gov]
Sent: Tuesday, November 20, 2007 2:33 PM
To: Neubauer, Michael L.
Cc: Tom Lackowski
Subject: Fw: ML RF Water

One question I asked Shigeki is the minimum flow for the collector. The information he gave is 37 liter per minute based on 45.8 KW actual heat dissipation at 18 C design temperature. I think the Klystron collector to be used for ILC is really a 300KW at 10 repetition rate, that will be used for 150 KW peak at 5 repetition rate (?), and that the minimum flow should maybe based on the either the design 300KW, peak 150KW, and not the actual 45.8KW (??), but no one knows. If that is the case, then current information need to be adjusted, and as Keith would say maybe out a circulation pump around the collector to ensure that minimum flow, and the same time obtain the high delta T at the collector.

Nov 2007, trying to find out the minimum flow in the collector. SO WHAT IS THE MINIMUM FLOW REQD FOR COLLECTOR? Question to the

same group

More on this....

----- Original Message -----

From: Bialowons, Wilhelm
To: Emil Huedem
Sent: Thursday, November 01, 2007 11:41 AM
Subject: RE: question

Emil, I assume the collector of the MB Klystron is designed for about 120 kW. Wilhelm

-----Original Message-----

From: Emil Huedem [mailto:huedem@fnal.gov]
Sent: Thursday, November 01, 2007 5:31 PM
To: Bialowons, Wilhelm
Subject: Re: question

Dear Wilhelm,

Thanks for the response.

Shigeki's flow is only 37 l/min, but he based on an actual heat dissipation of 45.8 and K=0.8.

37 l/min seems low (?right?) if I recall your discussion of minimum flow required to maintain proper velocity

The question of whether the collector to be used is design for higher heat dissipation is what I'm trying to find out, or how to find out what's the collector actual design heat.

Regards from sunny but low delta-T Batavia,
Emil

----- Original Message -----

From: "Emil Huedem" <huedem@fnal.gov>
To: "'Fukuda, Shigeki'" <shigeki_fukuda@kek.jp>
Sent: Thursday, November 15, 2007 9:10 AM
Subject: Follow Up Question

> Hello Shigeki-san,

>

> Oleg told me that the ILC Klystron Collector to be used is sized for 300KW
> load at 10 repetition rate at rated flow of about 150 to 160 liter per
> minute. And that it will be used for 150KW ILC peak load at 5 hz repetition
> rate, but the actual heat dissipation is about 45.8 KW. With this parameter,
> can the vendor provide what the minimum flow to the collector is?
> otherwise we'll stick with the 37 liter per min flow that you provided.


>

> I'm working with Chris Nantista to investigate if the loads can have low-flow
> high -delta T.

>

> Regards,
> Emil

Dec 4 2007 to Dec 16 2007 Interface with Mike Nubauer (HLRF point of contact)



12/14/07 E. Huedem

From: "Neubauer, Michael L." <neubauer@slac.stanford.edu>
 To: "Emil Huedem" <huedem@fnal.gov>
 Sent: Sunday, December 16, 2007 11:22 PM
 Subject: RE: Here is a cut at a 30F design

Hi Emil,

The current model is 22, and I'm expecting to get it to 30.

While we have been assuming the circulators need a stable operating condition. It's not clear that we need to do it with the water. (And I want to take advantage of the fact that we are trying to remove the circulators from the distribution system.) The other point is that the rf loads in the rf distribution may not be optimized in their individual cooling scheme. I suspect we can design very low pressure drop loads so they work in series.

I'm on vacation next week, and will be back at it Jan 7. Have a great holiday. Thanks for the feedback.

Mike
 |

Water Pump/ Skid
 Mike N: CFS stop here with valves tap???

22 F delta to 30

(From Shigeki's Oct 2007 Slide) General Calorimetric Calculation

- P(kW):Average power
 - ΔT (deg): delta C
 - Q(liter/min) : flow rate
- $$P \cdot 10^3 = \frac{4.18 \cdot Q \cdot 10^3}{60 \cdot \Delta T}$$
- then
- $$14.37 = \Delta T (\text{deg}) \cdot \frac{Q}{P} (\text{liter / min/ kW})$$
- put
- $$K = \frac{14.37}{\Delta T} = \frac{Q}{P} (\text{liter / min/ kW})$$

At MLI-KOM, Wilhelm pointed out the Thales guide line parameter of cooling K is **0.8 (liter/min/kW)**, and this value is a common accepted value from the cooling of the collector (by Toshiba engineer). Toshiba has better efficiency of cooling than the K=0.8 case. Though it is nice data, we use **K=0.8** as the standard collector cooling.

Current data for collector given as 45.8 KW, and 37 l/min.


In Oct 2007, We're told that ILC will use a Klystron design for 300KW at 10 rep rate, but will be use for 150KW peak at 5 Hz rep rate, actual heat dissipation given to us as 45.8 KW at K=0.8, flow = 0.8 x 45.8 = 37 l/min.

So, should we use this 150KW load also, flow = 120 l/min ?

At K=0.8, Delta T across collector always ~32F delta T




TESLA Cooling Scheme @ 5 Hz




Comparison – Tesla and Post RDR

Simplified Tesla lcv diagram




MAIN LINAC RE WATER SYSTEM (based on incomplete heat table dated Oct 31 2007), excluding Transformer




Comparison – Tesla and Post RDR

Simplified Tesla lcw diagram



MAIN LINAC RF WATER SYSTEM (based on incomplete heat table dated Oct 31 2007), excluding Transformer



For 45.8 KW collector, system delta T= 30 F

For 150 KW collector, system delta T=60F

Delta T = Total RF Heat Load (BtuH) / (500 * gpm flow)

pipe main already consider this, just need to add feedback piping loop, and ensure Heat rejection design for the higher load

1-1/2"	1-1/2"	pipe main to one rf
23.3	23.3	gpm main to one rf
30	60	delta T system
102	204	KW total
45.8	150	KW collector
36.64	120	l/min collector
9.7	31.7	gpm collector
32	32	delta T F collector

Specific V.E. List

POST RDR

		DESCRIPTIONS & "color" legend (DRAFT Dec 18 2007)	Who to develop short description
		(Gut-Feel) may not result to large savings	
		(Gut-Feel) may result to savings. Will be evaluated? (potential cost savings TBD)	
		MARC ROSS DEC 04, 2007 DIRECTION (LIST TO BE EVALUATED)	
		Will be evaluated By Others(HLRF), not CFS, whether high cost savings impact or not (not shaded) = Items that im Not Sure	
1	1	Provide one high efficiency cogen power / cooling plant on site and distribute power and 33 degree F chilled water throughout the facility, remove the power generation and chilling cost from the project cost	Steve
1	4	Eliminate one piping system by using process water as primary rejection for chilled water system w/#1 (using refrigerated heat pump as fancoils and standalone chillers for racks)	Emil
	4b	Eliminate one piping system by using process water as primary rejection for chilled water system w/#1 (using process cooled fancoils), warmer tunnel (item 6_15)	
1	6	Increase the delta T in the LCW and chilled water systems to 30 degrees, reduce flow, pipe size w/#1	Emil
5	10	Centralize the HVAC and reconfigure air flow from the ends	Lee
6	13	Let the temperature in the tunnel go to 104 degrees F during normal operation and local cool to 85 degrees where people are (consider increased cost for more frequent replacement)	Keith
6	15	Raise tunnel temperature to 103 degrees at all times (meets OSHA requirements) w/#13	Keith
8	16	Redesign the RF loads for more optimal process water flow	Mike
9	21	Modify top shaft HVAC to only process make up air, add blowers down shaft for recirculation	Lee
10	24	Reduce lighting level to egress limits	Tom
11	25	Reduce water pressure drop across components, minimize head pressure	Mike
12	35a	Consider using low mineral content water instead of LCW w/28 (design water system for low mineral water)	Keith
13	31	Allow different types of pipe materials: PVC, CPVC, HDPE, carbon fiber wrapped PE, etc in lieu of stainless steel	Rick
16	46	Use water cooled waveguide in the accelerator tunnel in lieu of air cooling	Mike
19	50	Develop loads that do not require low conductivity water	Fukuda
20	54	Use the waveguide pressurization system for cooling the waveguide (flow cooled gas inside the waveguide)	Mike
2	8	Define the maximum hydrostatic pressure for the collectors	Mike
4	27	Reexamine the hot changeout of modulator power supplies	Keith
8	41	Use a dessicant to dehumidify ventilation air	Lee
9	51	Evaluate each load individually to determine requirements	Keith / Mike
10	52	Establish power budgets for the relay racks (400 W / RF + 10% of power supplies)	Keith
11	53	Provide power supply that will work with warm water if necessary (quasi militarized)	Keith
NEW	NEW1	Eliminate Rack Skid and replace with just pump	Tom/Emil
NEW	NEW2	Eliminate one piping system by using chilled water only as primary rejection, eliminate process water distribution	Tom/Emil

Specific V.E. List

POST RDR

		DESCRIPTIONS & "color" legend (DRAFT Dec 18 2007)	Who to develop short description
		(Gut-Feel) may not result to large savings	
		(Gut-Feel) may result to savings. Will be evaluated? (potential cost savings TBD)	
		MARC ROSS DEC 04, 2007 DIRECTION (LIST TO BE EVALUATED)	
		Will be evaluated By Others(HLRF), not CFS, whether high cost savings impact or not	
		(not shaded) = Items that im Not Sure	
1	1	Provide one high efficiency cogen power / cooling plant on site and distribute power and 33 degree F chilled water throughout the facility, remove the power generation and Chilling cost from the project cost, by using alternative financing mechanism (e.g. ESPC, etc.) to transfer the construction costs of cogeneration to the project's future operating cost stream (without increase) where it can be amortized out of energy cost savings, thus practically eliminating the current costs for utility plants from the project construction. In other countries the ESPC concept might likely be replicated through investment loans. This idea would provide a centralized cogeneration plant at the central site with distribution throughout the tunnel. The cogeneration plant could likely provide cooling for the cryogenic, chilled water and process water systems and heat for desiccant dehumidifier regeneration, in addition to electrical power for the accelerator. Plant operation and maintenance is typically handled by the ESPC contractor and is also paid for out of the energy cost savings stream.	Steve
1	4	Eliminate one piping system by using process water as refrigerant heat pump on fans and stand alone chill	

Some VE list variations of this

Provide one high efficiency cogen power / cooling plant on site and distribute power and 33 degree F chilled water throughout the facility, remove the power generation and Chilling cost from the project cost, by using alternative financing mechanism (e.g. ESPC, etc.) to transfer the construction costs of cogeneration to the project's future operating cost stream (without increase) where it can be amortized out of energy cost savings, thus practically eliminating the current costs for utility plants from the project construction. In other countries the ESPC concept might likely be replicated through investment loans. This idea would provide a centralized cogeneration plant at the central site with distribution throughout the tunnel. The cogeneration plant could likely provide cooling for the cryogenic, chilled water and process water systems and heat for desiccant dehumidifier regeneration, in addition to electrical power for the accelerator. Plant operation and maintenance is typically handled by the ESPC contractor and is also paid for out of the energy cost savings stream.

Specific V.E. List

POST RDR

		DESCRIPTIONS & "color" legend (DRAFT Dec 18 2007)	Who to develop short description
		(Gut-Feel) may not result to large savings	
		(Gut-Feel) may result to savings. Will be evaluated? (potential cost savings TBD)	
		MARC ROSS DEC 04, 2007 DIRECTION (LIST TO BE EVALUATED)	
		Will be evaluated By Others(HLRF), not CFS, whether high cost savings impact or not	
		(not shaded) = Items that im Not Sure	
1	1	Provide one high efficiency cogen power / cooling plant on site and distribute power and 33 degree F chilled water throughout the facility, remove the power generation and chilling cost from the project cost	Steve
1	4	Eliminate one piping system by using process water as primary rejection for chilled water system w/#1 (using refrigerated heat pumps as fansills and standalone chillers for peaks)	Emil

Maintain reasonable (even lower) tunnel temperature to increase operating efficiency, extend equipment life, and improve operating environment. This VE item quoted impact of high ambient temperature involving electronic equipment of various grades of construction (Hardy, Average and weak), and the Corresponding loss of equipment life. Another is the energy loss associated with electrical resisitivity of conductors in distribution and equipment.

Specific V.E. List

POST RDR

		DESCRIPTIONS & "color" legend (DRAFT Dec 18 2007)	Who to develop short description
		(Gut-Feel) may not result to large savings	
		(Gut-Feel) may result to savings. Will be evaluated? (potential cost savings TBD)	
		MARC ROSS DEC 04, 2007 DIRECTION (LIST TO BE EVALUATED)	
		Will be evaluated By Others(HLRF), not CFS, whether high cost savings impact or not	
		(not shaded) = Items that im Not Sure	
1	1	Provide one high efficiency cogen power / cooling plant on site and distribute power and 33 degree F chilled water throughout the facility, remove the power generation and chilling cost from the project cost	Steve
1	4	Eliminate one piping system by using process water as primary rejection for chilled water system w/#1 (using refrigerated heat pump as fancoils and standalone chillers for racks)	Emil
	4b	Eliminate one piping system by using process water as primary rejection for chilled water system w/#1 (using process cooled fancoils), warmer tunnel (item 6_15)	
1	5	Increase the delta T in the LCW and chilled water systems to 30 degrees, reduce flow, pipe size w/#1	Emil
5	10	Centralize the HVAC and reconfigure air flow from the ends	Lee
<p style="font-size: 1.2em; margin: 0;">Use process water only as primary rejection. Eliminate Chilled water system by using multiple compressorized Fan coil (heat pump) to maintain 85F space</p>			
11	53	Provide power supply that will work with warm water if necessary (quasi militarized)	Keith
NEW	NEW1	Eliminate Rack Skid and replace with just pump	Tom/Emil
NEW	NEW2	Eliminate one piping system by using chilled water only as primary rejection, eliminate process water distribution	Tom/Emil

Specific V.E. List

POST RDR

		DESCRIPTIONS & "color" legend (DRAFT Dec 18 2007)	Who to develop short description
		(Gut-Feel) may not result to large savings	
		(Gut-Feel) may result to savings. Will be evaluated? (potential cost savings TBD)	
		MARC ROSS DEC 04, 2007 DIRECTION (LIST TO BE EVALUATED)	
		Will be evaluated By Others(HLRF), not CFS, whether high cost savings impact or not	
		(not shaded) = Items that im Not Sure	
1	1	Provide one high efficiency cogen power / cooling plant on site and distribute power and 33 degree F chilled water throughout the facility, remove the power generation and chilling cost from the project cost	Steve
1	4	Eliminate one piping system by using process water as primary rejection for chilled water system w/#1 (using refrigerated heat pump as fancoils and standalone chillers for racks)	Emil
	4b	Eliminate one piping system by using process water as primary rejection for chilled water system w/#1 (using process cooled fancoils), warmer tunnel (item 6_15)	

Eliminate process water by using chilled water only as primary rejection

19	50	Develop loads that do not require low conductivity water	Fukuda
20	54	Use the waveguide pressurization system for cooling the waveguide (flow cooled gas inside the waveguide)	Mike
2	8	Define the maximum hydrostatic pressure for the collectors	Mike
4	27	Reexamine the hot changeout of modulator power supplies	Keith
8	41	Use a dessicant to dehumidify ventilation air	Lee
9	51	Evaluate each load individually to determine requirements	Keith / Mike
10	52	Establish power budgets for the relay racks (400 W / Rack + 10% of power supplies)	Keith
11	53	Provide power supply that will work with warm water if necessary (quasi militarized)	Keith
NEW	NEW1	Eliminate Rack Skid and replace with just pump	Tom/Emil
NEW	NEW2	Eliminate one piping system by using chilled water only as primary rejection, eliminate process water distribution	Tom/Emil

Specific V.E. List

DESCRIPTIONS & "color" legend (DRAFT Dec 18 2007)			Who to develop short description
		(Gut-Feel) may not result to large savings	
		(Gut-Feel) may result to savings. Will be evaluated? (potential cost savings TBD)	
		MARC ROSS DEC 04, 2007 DIRECTION (LIST TO BE EVALUATED)	
		Will be evaluated By Others(HLRF), not CFS, whether high cost savings impact or not	
		(not shaded) = Items that im Not Sure	
1	1	Provide one high efficiency cogen power / cooling plant on site and distribute power and 33 degree F chilled water throughout the facility, remove the power generation and chilling cost from the project cost	Steve
1	4	Eliminate one piping system by using process water as primary rejection for chilled water system w/#1 (using refrigerated heat pumps as fossils and standalone chillers for peaks)	Emil
	4b	Elimin process	
1	5	Increa	
5	10	Centra	
6	13	Let the people	
6	15	Raise	
8	16	Redes	
9	21	Modif	
10	24	Redu	
11	25	Redu	
12	35a	Cons	
13	31	Allow	
16	46	Use w	
19	50	Devel	
20	54	Use th	
2	8	Defin	
4	27	Reexa	
8	41	Use a	
9	51	Evalu	
10	52	Estab	
11	53	Provid	
NEW	NEW1	Elimin	
NEW	NEW2	Elimin	

Red Item (Marc's selection from VE list)

Eliminate chilled water, use process water only for heat rejection

Consider using 30F water Delta T in RF

Warmer tunnel temperature to 104F during operation and local cool during maintenance

Consider low mineral content water instead of LCW

Consider using plastic pipe instead of steel/stainless steel


ACTUAL Marc Dec 4 2007 VE list

Evaluate Shaft 7 cost based on following selected list

SHAFT 7 (Process Water Only Scheme)

12/16/2007
E. Huedem

Total Operating Tower	12
Total Operating TowerTon	4297 T
Total Operating TowerMW	15.10 MW




BASIS

- 1 space maintain at 104 F
- 2 Load to air per RF 21.2 KW
- 3 Load to (RF) water per RF 103 KW
- 4 Racks per RF= 12 KW
- 5 Shaft 7 has 26 stations
- 6 Each Station = 4 RF
- 7 There are 2 fancoils per RF but shown as 2 large unit per station for delta T sizing purpose only
- 8 Rack Chiller system include self-contained chiller based on Liebert XDF (rack spacing issue, details later)
- 9 Fancoil based on AAON sizing
- 10 LCW system used for now. Load based on M.Neubauer email Dec 2007, full watercooled waveguide, with total 22 F delta T only, (HLRF to still refine to 30 delta T F)

Cost Reduction = ?

ACTUAL Marc Dec 4 2007 VE list

Evaluate Shaft 7 cost based on following selected list



Cost Reduction = ?


ACTUAL Marc Dec 4 2007 VE list

Evaluate Shaft 7 cost based on following selected list

SHAFT 7 (Process Water Only Scheme)

12/16/2007
E. Huedem

Total Operating Tower 12
Total Operating TowerTon 4297 T
Total Operating TowerMW 15.10 MW



TBD

- BASIS**
- 1 space maintain at 85 F
 - 2 Load to air per RF 21.2 KW
 - 3 Load to (RF) water per RF 103 KW
 - 4 Racks per RF= 12 KW
 - 5 Shaft 7 has 26 stations
 - 6 Each Station = 4 RF
 - 7 There are 2 fancoils per RF but shown as 2 large unit per station for delta T sizing purpose only
- system include self-contained chiller
vert XDF (rack spacing issue,

Variation: Replace w compressorized fancoils, maintain 85F

Cost Reduction = ?

on AAON sizing
used for now. Load based on
small Dec 2007, full watercooled
with total 22 F delta T only, (HLRF to
10 delta T F)


ACTUAL Marc Dec 4 2007 VE list

Evaluate Shaft 7 cost based on following selected list

SHAFT 7 (Chilled Water Only Scheme)

12/14/2007
E. Huedem

Total Operating Tower	14
Each Chiller Ton	1333 T
Total Operating Chiller Ton	3999 T
Total Operating TowerTon	4998 T
Total Operating TowerMW	17.57 MW



- BASIS**
- 1 space maintain at 85 F
 - 2 Load to air per RF 21.2 KW
 - 3 Load to (RF) water per RF 103 KW
 - 4 Racks per RF= 12 KW
 - 5 Shaft 7 has 26 stations
 - 6 Each Station = 4 RF
 - 7 There is 1 fancoil per RF but shown as 1 large one per station for delta T sizing purpose only
 - 8 Fancoil based on AAON sizing
 - 9 LCW system used for now. Load based on M.Neubaeur email Dec 2007, full watercooled waveguide, with total 22 F delta T only, (HLRF to still refine to 30 delta T F)

Cost Reduction = ?

Summary

Post RDR effort (Nov & Dec 2007) =updating HLRF heat table, delta T, value engineering session. started investigating with HLRF low flow-high delta T "Load

The number of suggestions (VE list, one water system, learning from tesla/xfel etc) should result to improvement and **cost reduction!**, but by how much? who's costing? No effort time??

I think chilled water "only" scheme (as suggested in VE list) should at least be considered / evaluated to find out "first cost" impact, unless the "heat load to air" in bedrock tunnel scheme is reduced much much further

From Oct GDE, it appear that heat Loads and requirement from other area system appear to be changing, increasing and tolerance tightening, so Requirement/criteria agreed by PM and area system will be important

Getting requirement/criteria is difficult,.. getting something that is agreed upon by the majority is more difficult, and it will probably take a while to get this.. For future detailed work (edr??).. it would be helpful to get what criteria/ requirement will be used as basis ...