




# EUDET COOLING and MECHANIC 15/01 LLR

Julien Giraud ([giraud@lpsc.in2p3.fr](mailto:giraud@lpsc.in2p3.fr))





# LPSC Leakless test



# LPSC Leakless test

Viscosité cinématique (m <sup>2</sup> /s)	9.52E-07
Mass volumique (Kg/m <sup>3</sup> )	1000
Diam.int tuyau aller (mm)	12
Diam.int tuyau retour (mm)	12
Perte charge échangeur (bar)	0
Débit (l/min)	3
P relative pompe (bar)	0.454
P relative réservoir (bar)	0
Limite résine lam turb	2000
L1 (m)	5.0
H1 (m)	4
L2 (m)	4
H2 (m)	4
L3 (m)	4
H3 (m)	4
L4 (m)	4
H4 (m)	2
L5 (m)	4.5
H5 (m)	3
Somme	
L6 (m)	4.5
H6 (m)	2
L7 (m)	4
H7 (m)	2
L8 (m)	4
H8 (m)	4
L9 (m)	4
H9 (m)	4
L10 (m)	5.0
H10 (m)	5.0
Aller	
Reynolds	557.2
Viscos (mdr)	0.45
Régime	Turbulent
Retour	
Reynolds	557.2
Viscos (mdr)	0.45
Régime	Turbulent
Général	
Pression appoint haut (bar)	-0.45
Hauteur sur leau appoint retour	0.00
Hauteur sur leau appoint aller	2.40
Hauteur sans la cloze retour	7.00
Hauteur sans la cloze aller	4.40
<b>ATTENTION DES SALES RESERVEES</b>	
Pression somme OK	

Répartition des pressions (Bar)	P Hauteur	P Requies	Somme	Somme
Partie pompe				
P1	0.18	0.10	0.179	0.18
P2	0.07	0.10	0.012	0.07
P3	-0.04	0.10	0.012	-0.04
P4	-0.25	0.20	0.012	-0.25
Point haut (PS)				
P5	-0.454	0.20	0.013	0.228
P6	-0.28	0.20	0.012	-0.28
P7	-0.09	0.20	0.012	-0.09
P8	-0.01	0.10	0.012	-0.01
P9	0.03	0.10	0.012	0.03
P10	0.00	0.10	0.179	0.228
Somme				
0.454				




## Exchanger determination

Caractéristiques circuit	
Puissance à évacuer (W)	150
Diamètre intérieur tuyau (mm)	4
Longueur échangeur (mm)	600
Débit (l/min)	0.3
Caractéristiques fluide	
Température fluide à l'entrée (°C)	18
Viscosité dynamique (Pa*s)	0.000952
Conductivité (W/(m*K))	0.598
Cp (J/(Kg*K))	4183
Mass volumique (kg/m <sup>3</sup> )	1000
Section (m <sup>2</sup> )	
1.26E-05	
Surface échange (m <sup>2</sup> )	
7.54E-03	
Vitesse (m/s)	
3.96E-01	
Régime écoulement	
Laminaire	
Reynolds	
1672	
Prandtl	
6.66	
Nusselt	
3.66	
h (w/m <sup>2</sup> )	
547	



ΔTmax cuivre (°C)	36.36
ΔTmax eau (°C)	7.17
ΔT entrée/sortie (°C)	39.94
T sortie (°C)	57.94
Perte charge échangeur (bar)	0.0045



## Leak less loop determination

# LPSC Leakless test

Some pictures:




Top of loop => -0.8 bar => cavitation start (extrem point) => LEAK LESS SYSTEM

## 1° ANGLE



Alveolar structure => about  $46.1^\circ$  (CATIA MODEL) => not a problem

SLAB and COOLING angle  $45^\circ$  => IMPORTANT FOR THE COOLING INTEGRATION



## 2° ADAPT / DIFF SUPPORT


- Other support in development ? Cable support ?
- 0.8 mm free for LPSC side support (half of the diff)



**ADAPT / COOLING SUPPORT: OK ?**

## 3° ETD or HCAL


Note that the cooling support is fix on the thin (2mm) carbon plate => We have to check if no problem



- Rails:** aluminium or composite
- Pipe connectors:** disconnection of cooling threw the rails or development of tiny connectors in front end.

## IMPORTANT NEEDS FOR COOLING AND ADAPT / DIFF SUPPORT

- Final thickness of the slabs ( U or H ).  
(distance between copper drain)
- Thickness of the copper drain (0.4 or 0.5 mm)
- POWER dissipation : DIFF and ADAPT ?
- TOTAL POWER dissipation ?



### Cooling during EUDET life:

Do we have to build a small autonomous cooling station for EUDET ? (small chiller / flow measurement / Temperature measurement), the existing installation going on for further tests.

**Or** can we connect the cooling system to existing cooling on beam test areas?



# LPSC Leakless test

---