



BASELINE ASSESSMENT WORKSHOP 2

CONVENTIONAL FACILITIES AND SITING GROUP

Positron Source Relocation (10 Hz)

V. Kuchler



Basic CFS Assumptions

- **Main Linacs - Baseline**

- **RDR Configuration**

- **Undulator Source was Located at the 150 GeV Point in the Main Linac**
 - **A Positron Transport Line was Required to Connect the e^+ Source Output to the 400 MeV to 5 GeV Accelerator**
 - **Two Main Linac Tunnels, No KCS and Hence No Interference from the Large Waveguide and CTO's**
 - **CFS Impact from the Positron Source was not Fully Optimized and Resulted in Some Inflated Criteria w/r to CFS Underground Volume**
 - **The Impact of the KCS RF System w/r to the Original Positron Source Location on the Size of a Single Tunnel was not Considered**
 - **For the Purpose of this Exercise, the RDR Positron Source Criteria was Corrected to Better Reflect Current Design Development**
 - **Comparison will be Based on Reduced Bunch Number, 1312 Bunches per Train at 5 Hz**

- **Damping Ring - Baseline**

- **Comparison will be Based on a 3.2 km 7.5 m Diameter Damping Ring initially to House 2 Rings (1 e^- & 1 e^+) But Sized to Allow Upgrade Path to 3 Rings (1 e^- & 2 e^+)**



CFS Impacts

- **General Considerations**

- **Only the 3 Major CFS Cost Drivers were Reviewed for this Exercise**
 - **Civil Construction**
 - **Process Cooling and HVAC**
 - **Electrical**
- **Civil Construction**
 - **No Fundamental Impact**
- **Process Cooling and HVAC (Mechanical)**
 - **Mechanical Equipment and Loading Increases as Scaled by Power Loads for the Damping Ring**
- **Electrical**
 - **Electrical Equipment and Distribution Increases as Scaled by Power Loads for the Damping Ring**



SUMMARY HEAT LOAD			
Low*=Reduced Bunch numbers			JAN 13 2011
<u>Positron Source Relocation</u>			
	ML POWER in MW		
	Low*-5Hz	Low*-10Hz	
KCS	63.6	(less than 5 hz Low)	
DRFS	61.31		
RDR (ML) =134 MW (reference)			
	DR total POWER in MW		
	Low*-5Hz- 3.2Km -2 rings	Low*-10Hz- 3.2Km -2 rings	FULL-5Hz- 3.2Km -3 rings
DR	8.44	12.44	14.81
RDR (DR) =26.3 MW (reference)			
green= numbers to be checked			



SUMMARY POWER LOAD			
Low*=Reduced Bunch numbers			JAN 13 2011
<u>Positron Source Relocation</u>			
	ML POWER in MW		
	Low*-5Hz	Low*-10Hz	
KCS	120	113	
DRFS	131		
RDR (ML) =134 MW (reference)			
	DR total POWER in MW		
	Low*-5Hz- 3.2Km -2 rings	Low*-10Hz- 3.2Km -2 rings	FULL-5Hz- 3.2Km -3 rings
DR	12.81	16.8	19.18
RDR (DR) =26.3 MW (reference)			
green= numbers to be checked			



Baseline to Relocated Positron Source (10 Hz)

- **Civil Construction**
 - **No Fundamental Change**
- **Process Cooling and HVAC**
 - **Increase in Cooling Towers for Process Water (DR)**
 - **Increase in Cooling Tower Pump and Accessories for Process Water System (DR)**
 - **Increase in Chiller Capacity (DR)**
 - **Increase in LCW System (DR)**
- **Electrical**
 - **Increase in Medium Voltage Substations (DR)**
 - **Increase in Medium Voltage Distribution and Transformers (DR)**



					JAN 14 2011
POSITRON SOURCE RELOCATION					no drfs 10HZ data (assume same as KCS)?
** (CFS cost are for Civil, Mechanical, & Electrical only, in Million 2006\$)					
		5Hz Low*	10Hz Low*	delta in M\$	
	KCS CFS* cost	\$ 756.0	\$ 756.0	\$ (0)	**No additional Cost needed
	DRFS CFS* cost	\$ 883.4	\$ 883.4	\$ -	**No additional Cost needed
		5Hz Low* 3.2 Km 2 rings, 7.5m Dia	10Hz Low* 3.2 Km 2 rings, 7.5m Dia	delta in M\$	
	DampingRing CFS* cost	\$ 134.8	\$ 139.5	\$ 4.7	**1.1M elec, 3.6M mech
<u>Upgrade path from 10Hz 3.2Km 2 rings to 5hz 3.2Km 3 rings</u>					
		10Hz Low* 3.2 Km 2 rings, 7.5m Dia	<u>UPGRADE PATH</u> to 5Hz <u>Full</u> 3.2 Km <u>3 rings</u> , 7.5m Dia	delta in M\$	
	DampingRing CFS* cost	\$ 139.5	\$ 142.1	\$ 2.6	**0.7M elec, 1.9M mech



Upgrade Back to Full Power

- *The Primary Upgrade will be the Installation of the Second e⁺ Damping Ring*
 - *Tunnel is Already Sized to Receive the Second e⁺ Damping Ring*
 - *Mechanical and Electrical Equipment will have to be Added to Support the Additional Ring*
- *Upgrade should be Fairly Straightforward from the CFS Standpoint*



Summary

- *Positron Source Relocation Needed Some Adjustment to the RDR Information to Provide an Accurate Comparison*
- *KCS Impact was not Factored into the Original Positron Source Location*
- *The Biggest CFS Impact is in the Process Cooling Water and HVAC and Electrical*