



Cost Impacts of two e- ML cycles at $\sqrt{s} \leq 250 \text{ GeV}$

**purpose:
not to generate a new ILC estimate,
but to facilitate SB2009 decisions**

**Peter H. Garbincius, Fermilab
BAW-2, SLAC, January 21, 2010**

last modification – 21jan2011 – 1130 PST

filename: PHG-BAW_Cost_Impact_10Hz.ppt




Outline of this presentation

- call it: **1 + 125x125** normally: **250x250**
- factorize: 1 + 125x125, then Centralized e+ Source
- pulse structure – starting point
- limitations in this analysis
- Impact Matrix, more details for e- ML & DRs (τ_{damp})
- Cost Impact Table for 1 + 125x125
- My hallucinations on Centralized e+ Source
- A little bit clearer picture
- Cost Impact Table for Centralized e+ Source
- Summary


- Today's question: how much **more** will it cost to provide this extra capability?
- I'll concentrate on ML and DR for this presentation and then add cost impact of moving
Positron Source to 250 GeV in e- ML
- e- DR must produce 2 pulses every 200 msec, which is 10 Hz
- e+ DR must produce 1 pulse every 200 msec, which is 5 Hz. It has a 50% RF duty factor, which will increase its PEAK RF power required by
~15% - S. Belomesnykh, Geneve, Oct 2010

Nice illustration that I'll "borrow" from Shigeki!

Electron Beam



Positron Beam



I will **not** consider impacts of this
150 + \leq 125x125 pulsing at **full #** of bunches
– per Nick Walker’s BAW-2 instructions

Although there has been much discussion of
“optimizing” the length of the undulator and
choice of either quarter-wave transformer or
flux concentration as collection stage of the
positron source, I will assume a **single** choice
will apply to the cases under consideration
and therefore there is **no cost differential**.



Cost Impact Matrix for 150 + \leq 125x125 relative to 250x250 @ reduced # bunches

150 plus 125*125	Tech. Comps.	RF Power	Cryo Power	Civil Tunnels	Civil Cavern*	Civil Buildings	Electrical Power	Thermal Cooling	Notes * includes alcoves & tunnel widenings
e- source	✓	✓	✓		?		✓	✓	must provide 10 Hz pulses
e+ source	✓				✓		✓	✓	none, no extra load on γ target/dump
e- DR	✓	✓	✓				✓	✓	provides 150 and \leq 125 GeV pulses
e+ DR	✓	✓	✓				✓	✓	needs more peak RF power for 50% df
e- RTML		✓	✓				✓	✓	must double pulse BC-1
e+ RTML									no impact
e- ML (&BC2)	✓	✓	✓			KCS	✓	✓	must provide 125 and \leq 125 GeV pulses
e+ ML (&BC2)									no impact
e- BDS				✓	✓			✓	MPS & spent 150 GeV e- beam to dump
e+ BDS									no impact
Exp Hall									no impact
Common							✓		only Master Substation

- Major costs are for **e- Main Linac & both Damping Rings**, so we will concentrate only on these systems
- Different civil construction (enclosures) for e+ Source
- e- Source, e- RTML (BC-1) and e- BDS (dump only) have small increased power ~ small extra costs



Chris A – minor impact on RF

- More details and discussion in backup slides



RF & wigglers for DRs

conventional components are the same

lattice	SB2009	SB2009	SB2009
	LowP 5 Hz	LowP 10 Hz	LowP 10 Hz
beams	e+/e- ea	e+ Ring	e- Ring
reference-page	4-11,30	4-28,30	ref 4 p 30
Circumference (m)	3238	3238	3238
# bunches per DR	1305	1305	1305
damping time ms	24	13	18
RF Voltage MV/DR	7.5	13.4	10.4
# RF cavities/DR	6	9	9
# klystrons/DR	2	3	3
Wiggler B (Tesla)	1.6	2.4	2.4
Wiggler period (m)	0.4	0.28	0.28
Wiggler lgt ea (m)	2.45	1.72	1.72
Wiggler lgt/DR (m)	78	75	75
# wigglers/DR	32	44	44

tab: DR-info

different wigglers
assume same cost - MP



SR photon absorbers in wigglers

- cost estimates were not included in RDR or in any of the SB2009 and BAW-2 analyses
- Hope that they cancel in the differential cost sense...



Cost Differentials for ML & DR


1312 bunches	250x250		150+125*125		Cost diff M ILCU	Notes
	Quantity	Cost M ILCU	Quantity	Cost M ILCU		
Main Linac - KCS						
modulators & PS for e- ML	499/2	76.9	499/2	77.0	0.2	ChrisJ estimate (+0.2%) & ChrisA note
cryogenics plants e- ML	5*4.12 MW		5*3.35 MW		0	lower, so no impact
cryogenics plants e+ ML	5*4.12 MW		5*2.65 MW		0	lower, so no impact
RF power	66 MW		59 MW		0	no impact, PHG => Emil 12jan2011
other electrical power	54 MW		54 MW		0	same, no impact
thermal cooling	64 MW		57 MW		0	lower, so no impact
Damping Rings - 2 rings - 3.2 km						
technical components		276.3		298.4	22.1	see detailed RF & wiggler change list
cryogenic plant e- DR	1.18 KW 4.5K	3.5	1.64 KW 4.5 K	4.3	0.8	100% df + 2*50% duty factor
cryogenic plant e+ DR	1.18 KW 4.5K	3.5	1.55 KW 4.5 K	4.1	0.6	100% duty factor & 50% duty factor
cryo accessories e- DR		3.1		3.1	0	same, no impact
cryo accessories e+ DR		3.1		3.1	0	same, no impact
cryo distribution e- DR		4.2		4.2	0	same since # end boxes the same
cryo distribution e+ DR		4.2		4.2	0	same since # end boxes the same
CFS: Civil		107.3		107.3	0	same, no impact
CFS: Electrical Power	12.8 MW	16.3	16.8 MW	17.4	1.1	CFS did this better than PHG's P ^α
CFS: Thermal Cooling	8.5 MW	24.1	12.4 MW	28.2	4.1	CFS did this better than PHG's P ^β
e- Src - Modulators & PS					1.2	need to double pulse, same E
e- Src - Electrical & Cooling					3.2	PHG guess/scale for RF & Cryo
e- Cryogenics capacity					2.9	2X dynamic cryogenics load
e- RTML Modulators & PS					0.2	need to double pulse BC-1 at 5 GeV
e- RTML Electrical & Cooling					0.2	PHG guess/scale for RF & Cryo
e- RTML Cryogenics capacity					0.4	2X dynamic cryogenics load

tab: 10 Hz summary

total increase = 37 M divide by 6,618 M ILCU = +0.56%

Cost Difference for e^+ Source at 150 GeV point = RDR(1) = SINGLE TUNNEL RDR
at 250 GeV point = SB2009

RDR(1) Ref: ILC-CE-1.1649.0016 - 50 DEC 2006



Ref
 SB2009: 6-11-BCD - 20 Nov 2009

SOME INCONSISTENCIES WITH NORBERT COLLINS - 12 JULY 2010 DRAWINGS

Low Energy Operations
 PHG - BAW-2 SLAC - 21 Jan 2011


ILC - Global Design Effort

TUNNELS	RDR(1)	SB2009	Diff
Beam Line 150 GeV	8327 m	7969 m	358 m
Service tunnel inc Protection undulator	3594 m	3236 m	358 m
TOT 8 diff/align	11,921 m	11,205 m	716 m

BUT watch TUNNEL WIDENINGS!

neater optics sketch for Centralized Positron Source

positron system is schematic only: not to scale or position





cost impacts of moving of e+ source

Cost Differentials for Centralized e+ Source - M ILCUs	Savings	Additions	Notes:
one set of MPS sacrificial collimators, abort, & dump	???		never estimated for RDR
301 m tunnel (for above)	3.0		
301 m tunnel widening (for above)	4.7		
4 m dia rad material handling shaft & grouting	9.5		
Radioactive Materials Handling & Storage Bldg	3.1		
KAS e+ target station & acceleration to 400 MeV	28.2		- see next page for details
electrical power	???	???	not considered yet by CFS
thermal cooling	???	???	not considered yet by CFS
spent 150 GeV e- from undulator => dump 1,166 m dogleg, min FODO, min instrumentation, rastering?		???	to e- tune up dump or to e+ primary dump (backwards)?
100 msec beam switches		???	
corrector magnets for dual energy trajectories		???	
LET bypass around undulator for beam to I.P. (620 m)		???	- do we need/want this?
total change (= savings minus additions) - M ILCU	48.5	???	M ILCU

150 + 125x125

+ 37 M ILCU (more)

Centralized e+ Source

- 48 M ± ???

tab: needs

Summary - 11 ± ?? M ILCU



RDR Keep-Alive Source Estimates

Cost Estimating of KAS - components

John Shepard - RDR	K ILCU - 2007	Notes
KAS laser (0.5)	0	also needed for aux. source, no differential
KAS gun (0.5)	0	also needed for aux. source, no differential
Sub-Harmonic Buncher (2)	0	also needed for aux. source, no differential
500 MeV KAS e- accelerator	0	also needed for aux. source, no differential
everything below was needed for second e+ production station & acceleration to 400 MeV		
e+ production target	3,937	
Adiabatic Matching Device	2,329	
Target & AMD housing/shield	1,123	
SW Cavities (2)	124	
TW Cavities (12)	3,097	
Warm Station High Level RF (14)	10,839	
SW HL RF distribution (2)	380	
TW HL RF distribution (12)	1,388	
Controls - pro-rated	657	
KAS Instrumentation	968	
KAS Dumps & Collim	210	
KAS Vacuum	780	
KAS Conventional Magnets	1,177	pro-rate KAS magnet costs from PS costs
KAS Power Supplies	1,180	

totals

28,189 K ILCU - 2007

tab: needs

Backup Slides



(skip) quick thoughts on e- ML power


Remember that we started with capability of one e- ML pulse at 250 GeV, and now we are considering the maximum of 150 GeV + 125 GeV (gross sum = 275 GeV), but we have to look at details of three things:

- **relative widths of t_{fill} , t_{beam} and t_r**
these will affect total power and cooling and cryogenic plant power due to dynamic cryogenic loads in the cavities
- **efficiencies of klystrons running at 60%/50%**
- **capabilities of modulators and power supplies**
- **RF parameters and Q_L optimized for 150 GeV, will not be matched at $E < 150$ GeV (reflections)**

RF pulse for constant klystron power

$$\tau = 1/(2\pi f_o) * 2 * (V_c / I_b) / (R / Q_o)$$

where $f_o = 1.3 \text{ GHz}$, $R / Q_o = 1036 \Omega$




DRFS for 150 + ≤ 125x125

- Shigeki just sent 110115A on Sunday, Jan 16 which said, “In the case of low-energy 10 Hz case, DRFS HLRF hardware configuration is the same as SB2009 and not cost change.”
- Shigeki did **not** send power and cooling requirements for 150 + 125x125 to CFS
- I didn’t see Shigeki’s presentation until yesterday
- Shigeki previously said details with new estimates will not be available until Summer 2011
- So I can’t say too much more on DRFS...

RF parameters for KCS

KCS 150 + 125*125 @ 6.2 mA		e+ 125	e- 150	e- 125 *
I_beam	mA	6.2	6.2	6.2
t_fill	msec	0.432	0.518	0.452
t_beam	msec	0.702	0.702	0.702
t_rf	msec	1.134	1.22	1.154
fall time τ	msec	0.623	0.748	0.623
* note that Q_L for e- is set for no reflection during 150 GeV pulse => reflections during 125 GeV pulse				





KCS parameters for 150 + 125*125

- Keep $t_{\text{beam}} = 0.702$ msec, $I_{\text{beam}} = 6.2$ mA
- Need parameters: does t_{fill} change between 150 and 125?, ChrisN (1/12) and ChrisA (1/14) has for constant power klystron output pulse

$$t_{\text{fill}}(150 \text{ GeV}) = 0.517 \text{ msec}$$

$$t_{\text{fill}}(E)/t_{\text{fill}}(150 \text{ GeV}) = \ln(1+E/150 \text{ GeV})/\ln(2)$$

$$t_{\text{fill}}(125 \text{ GeV}) = 0.874 * t_{\text{fill}}(150) = 0.452 \text{ msec}$$

$$\text{reflected power ratio} = (1/4) * (1-E/150)^2 \sim 0.7\%$$



Dependence of Cryo Dynamic Loads

$$\text{RF load} \sim V_{\text{cav}}^2 * (t_{\text{beam}} + 1.11 * t_{\text{fill}})$$

$$\text{Input Coupler load} \sim V_{\text{cav}} * (t_{\text{beam}} + t_{\text{fill}}) * I_{\text{beam}}$$

$$\text{HOM (beam) load} \sim I_{\text{beam}}$$

Don't ask, I don't have simple breakdown by dynamic load component, or even dynamic to static sum, only listed as function of coolant temperature (2 K, 5 K, 40 K)

Cryo Loads: Full Power (both) 10^* 4.42 MW

Reduced # bunches: KCS 10^* 4.12 MW

DRFS 10^* 4.72 MW

- ChrisN incorrectly had $\ln(1 + \textcolor{red}{sqrt}(E/150))/\ln(2)$ which gave $t_{\text{fill}}(125 \text{ GeV}) = 0.483 \text{ msec}$, instead of 0.458 msec when Q_L is set for 150 GeV which TomP used for the cryogenics dynamic load for 125 e-

What is the difference for e- beam?

- $P_{\text{cryo}}^{\text{dynamic}}(0.483 \text{ msec}) = 10 \times 3.55 \text{ MW} - \textcolor{red}{X}$
- $P_{\text{cryo}}^{\text{dynamic}}(0.458 \text{ msec}) = 10 \times 3.54 \text{ MW} - \textcolor{red}{\checkmark}$