



# ***Cost Impacts of Reduced # Bunches per Train***

**purpose:  
not to generate a new ILC estimate,  
but to facilitate SB2009 decisions**

**Peter H. Garbincius, Fermilab  
BAW-2, SLAC, January 19, 2010**

***latest modification: 19jan2011- 1400 PST  
filename: PHG-BAW\_Cost\_Impact\_LowP.ppt***



## *Outline of this presentation*

- Don't call it "Low Power"
- Questions: savings, upgrade/restore, invest
- Cost Differentials ... today vs. tomorrow
- What we can quickly learn from RDR estimate
- RF System Choices for ML for KCS and DRFS
- DR tunnel: 6.4 km @ 5 m => 3.2 km @ **7.5 m** and changes in RF and wiggler quantities
- Electrical Power, Cooling, and Cryo comparisons
- Cost Difference Summaries and Roll-up
- Restoration back to 2625 bunches/train
- Ending notes

## *Let's not call this "Low Power"*

- It is technically *reducing the number of bunches* from the RDR nominal baseline of **2625** bunches/train to **1312** bunches/train, and by *restoring Luminosity* by *more optimized focusing* at I.P. or by using *traveling focus*.
- We need to maintain **250x250 GeV** capability and adequate luminosity
- Cannot start with RF for lower Energy and then upgrade later. This would only make sense if we installed fewer CMs & added more later

- We **start** with the BAW-1 decisions: single-tunnel, KCS or DRFS, cavity gradient spread, plus 6.4 km racetrack DR.
- For calculational purposes, we also group the 2\*12 RF units (= 3 CM = 26 cavities) associated with BC-2 with the ML CMs and HLRF, assuming they can be similarly powered. This is just an assumption and does not imply a choice of single-stage Bunch Compressor.
- **Question:** How much can we **save** if we reduce number of bunches/train 2625 => 1312?
- What is the **upgrade path** back to 2625 bunches?
  - What would it **cost to restore** 2625 bunch capability?
  - What should we **invest** in utilities: civil, electrical, cooling, cryo, etc. from to **facilitate** restoration?

- We will not generate complete estimates, just see how much the configuration changes under consideration could save relative to the **6.618 B ILCU** RDR estimate.
- Today, we will not consider “10 Hz” which is really **150 GeV e-** for positron production & **125x125 GeV e+e-** collisions at IP where both pulses are interspersed at **5 Hz** each nor impact of moving e+ source to end of ML  
*..... tomorrow!*

- Thank you to many people who have worked hard to produce these *quantitative* impacts:  
DR: Susanna, RF: ChrisN, ChrisA, Shigeki  
Cryo: TommyP,  
CFS: Vic, Tomski, Emil, Randy, Lee ...
- Again, information, specifications, requirements *came late*
- CFS and I struggled to get these data on paper, we knew what we had to do, but *insufficient opportunity for cross checking*  
I'll point out errors, omissions, inconsistencies



## Cost Impact Matrix

Reduce # bunches 2625 => 1312 @ 250x250 GeV

reduced # bunches	Tech. Comps.	RF Power	Cryo Power	Civil Tunnels	Civil Cavern*	Civil Buildings	Electrical Power	Thermal Cooling	Notes
									* includes alcoves & tunnel widenings
e- source	✓	✓	✓				✓	✓	reduced laser and cryo RF
e+ source	✓	✓	✓				✓	✓	cryo RF and cooling of photon dump
DR	✓	✓	✓	✓	✓	✓	✓	✓	reduced circumference to 3.2 km
RTML	✓	✓	✓				✓	✓	only BC1 (BC-2 included under ML)
ML (& BC-2)	✓	✓	✓			KCS	✓	✓	# HLRF components (LLRF impact)
BDS	✓	slight	slight				slight	slight	traveling focus components only
Exp Hall									no impact yet
Common							✓		only Master Substation

Major costs are for **Main Linacs & Damping Rings**,  
so we will concentrate only on these systems.  
e- & e+ Sources, and RTML have reduced power  
BDS traveling focus systems ~ small extra costs  
CFS did include impact on Master Substation

## *other savings not considered:*


- Water Cooling for Main Dumps (2), Tune-Up Dumps in BDS (2), & Photon Dump ( $e^+$  Src): the mechanical systems and capacities are sized for 500x500 GeV operations, so could reduce number of pumps and HEXs for reduced bunch number, and add later
- Cryogenics Plant cost estimates include multiple compressors, some of which might be able to be deferred for low bunch number configuration and added later to restore full Power



# *RF pulse for constant klystron power*

$$\tau = 1/(2\pi f_o) * 2 * (V_c / I_b) / (R / Q_o)$$

where  $f_o = 1.3 \text{ GHz}$ ,  $R / Q_o = 1036 \Omega$



- Both accelerates 1312 bunches per train
- ChrisA – KCS reduces beam current from 9 mA => 6.2 mA, reducing  $t_{\text{beam}}$  and keeping  $t_{\text{rf}}$  constant which minimizes power, cooling, and dynamic load on cryogenics but only reduces # klystrons from 714/699 to 499/477 or 70%/68% (installed/powered)
- Shigeki – DRFS drops every other bunch keeping  $t_{\text{beam}}$  constant, which reduces # klystrons by 50%, but increases  $t_{\text{fill}}$  and  $\tau$  which increases power, cooling, and dynamic load on cryogenics
- Which is more optimal approach?

### A. FULL POWER


(our interpretation)

Low Power to be checked

**DRAFT**  
12/06/2010  
E. Huedem

# KCS power flow

## 27 Unit KCS Average Power Diagram Corrected for Spare and Overhead






## ***DRFS for Reduced # Bunches***

- Shigeki sent multiple choices on Sunday, Jan 16: designated 091216, 100327, 100601, 110115A
- I'll use 110115A which includes extra cost for extra capacity needed for longer  $t_{rf}$  for DC PS and Modulators, but not for Klystron
- Shigeki did apply “learning curves” of 89-90% or quantity pricing reduction for klystrons, modulators, & power supplies
- Shigeki previously said details with new estimates will not be available until Summer 2011

# RF parameters

250 GeV



Scenario	Full Power	Reduced # bunches	
RF configuration	KCS & DRFS	KCS	DRFS
beam current I_beam	9	6.2	4.5
# bunches/train	2625	1312	1312
# trains per second	5	5	5
max energy	250	250	250
V_cavity (during beam pulse)	32.70	32.70	32.70
length of beam pulse t_beam	0.969	0.702	0.969
length of fill pulse t_fill	0.595	0.862	1.19
length of RF pulse t_rf	1.564	1.564	2.159
fall time (exponential) $\tau$	0.859	1.244	1.717

— Full P - 2625 bunches - 9 mA  
 - - KCS - 1312 bunches - 6.2 mA  
 - - DRFS - 1312 bunches - 4.5 mA



## *Dependence of Cryo Dynamic Loads*

$$\text{RF load} \sim V_{\text{cav}}^2 * (t_{\text{beam}} + 1.11 * t_{\text{fill}})$$

$$\text{Input Coupler load} \sim V_{\text{cav}} * (t_{\text{beam}} + t_{\text{fill}}) * I_{\text{beam}}$$

$$\text{HOM (beam) load} \sim I_{\text{beam}}$$

Don't ask, I don't have simple breakdown by dynamic load component, or even dynamic to static sum, only listed as function of coolant temperature (2 K, 5 K, 40 K)

Cryo Loads: Full Power (both)  $10^*$  4.42 MW

Reduced # bunches: KCS  $10^*$  4.12 MW

DRFS  $10^*$  4.72 MW





## *7.5 m diameter DR tunnel for 3 rings*

- Prior SB2009 had 6.5 m dia DR tunnel
- US 6.5 m 11.067 K/m, Asia 6.5 m 10.458 K/m
- US 7.5 m 12.166 K/m, Asia 7.5 m 11.952 K/m
- Difference between 7.5 m and 6.5 m diameter tunnel for for 3,223 meter DR:  
US 3.6 M ILCU, Asia 4.8 M ILCU
- Both US and Asia estimates include excavation & concrete finishes
- This above analysis of US estimate did **NOT** include extra costs for tighter turning TBM for 3.2 km DR, although detailed CFS estimate did




### TBM tunnel + finishing cost

Japan fit normalized at dia = 5 m to RDR value




(This does not include land developing cost.)

### Hanson/Tracy Lundin: Chicago TARP – Deep Tunnel




Atsushi @  
BAW-1





# *How can 3 rings fit in the DR tunnel?*

## CEBAF 4-ring circus



3 CM IN ONE TUNNEL  
6 METER TUNNEL SHOWN WITH NOTCHED FLOOR  
(VERY DIFFICULT SOLUTION)  
THE OUTER CIRCLE IS 6.5 METERS



# Damping Ring Magnets

## RF cavities & wigglers on next page

Positron-Source-Location-PHG-19nov2010.xls/DR-counts					1.0323						dipole KLs are OK						3. how do the cost of sextupoles scale with Sx term? F						
Peter H. Garbincius - re-do damping ring counts					7dec2010-3:30 PM																		
<a href="https://wiki.lepp.cornell.edu/ilc/bin/view/Public/DampingRings/#Damping_Rings_Parameters_and_Lat">https://wiki.lepp.cornell.edu/ilc/bin/view/Public/DampingRings/#Damping_Rings_Parameters_and_Lat</a>																							
	from RDR table			k1 arcs =		0.287 k max=		max k1 =		0.585		all quads are 0.3 m											
per ring - 5 GeV	OCS6 - RDR DR & Magnets - 6.7 hex							per ea	per tot	DCO4 - Susanna 10/09 - 6.4 race					per ea	per tot	SB2009 - 14dec09 - 3.2 race					per ea	per tot
Main e- DR & e+ DR each	#	length m	max KL	unit	field			K 2006	K 2006	#	lgt	field		2006	2006	#	lgt	field		2006	2006		
RDR Dipoles 6 m	114	6	0.0524	1	0.145	T		63.66	7,257														
RDR Dipoles 3 m	12	3	0.0262	1	0.145	T		38.82	466														
DCO4 arc dipoles			above is		about right					200	2	0.27	T	39.51	7,902								
DSB3 arc dipoles - type 1			bend angle													68	2.7	0.26	T	51.36	3,493		
DSB3 arc dipoles - type 2			at 1 m per													60	2.7	0.36	T	71.12	4,267		
chicane dipoles - 1 m - 0.27	no chicanes?		6 m dipole	Susanna: chicanes omitted but needed						48	1	0.27	T	19.76	948	48	1	0.27	T	19.76	948		
Quads V1	551	0.3	0.31	1/m	6.1	T/m		12.24	6,747														
Quads V2-V3-V4	196	0.3	0.31	1/m	17.3	T/m		16.84	3,301														
Quadrupoles - 0.3 m - 12 T/m		Q is bend at 1 m			right range					692	0.3	12	T/m	16.84	11,654								
Quadrupoles # 1 Q30L300 V2	but RDR was Q60 L30 but pole tip radius was 0.03 m										all = 0.3 m		interpolate below			204	0.3	11	T/m	14.31	2,920		
Quadrupoles # 2			K1 V1 =	0.287		2.8361					are these quads all the same?					128	0.56	8.3	T/m	26.95	3,449		
Quadrupoles # 3			K1 V2-4 =	0.725	0.3 m	2.5261					use same cost as RDR V2					128	0.73	11.9	T/m	32.84	4,204		
Quadrupoles # 4				0.939	0.15 m							Gmax=	12.434	close!		4	0.215	16.9	T/m	10.44	42		
Quadrupoles # 5																30	0.43	14.7	T/m	20.71	621		
sum # main Quadrupoles =	747									692						494		interpolate below					
sextupoles	480	0.25	0.24	1/m^2	16.76	T/m^2	4.799	2,303	392	0.25	215	T/m^2	11.22	4,400	280	0.25	150	T/m^2	9.956	2,788			
orbit corrector magnets	300	0.25	0.002	1	0.133	T	4.756	1,427	300	0.25	0.133	T	4.756	1,427	300	0.25	0.133	T	4.756	1,427			
skew quads	240	0.25	0.03	1/m	2.0	T/m	12.1	2,903	240	0.25	2.2	T/m	12.1	2,903	240	0.25	2.2	T/m	12.1	2,903			
check arc dipoles int B*dL (T-m)	104	expect	104.4	T-m	sum07	25,192	sum06	24,404	108	T-m - c	sum07	30,179	sum06	29,234	106	close	sum07	27,936	sum06	27,062			
Common Injection/Extraction/Abort																							
RTML6 dipoles (inj/extr/abort	3	D60L2000								same					same								
Quads V2 (inj/extr)	12									same					same								
inj/extr kickers	40									same					same								
inj/extr septa	4									same					same								
abort kickers	1									same					same								
abort septa	1									same					same								



# *RF & wigglers for DRs – 5 Hz*

**full P – 3 rings**

lattice	RDR-OCS 6	DCO 4	SB2009	SB2009	SB2009
	20-Apr-07	full-P 5 Hz	LowP 5 Hz	full-P 5 Hz	full-P 5 Hz
beams	e+/e-	e+/e-	e+/e-	e-	2* e+
reference-page	ref 3 p 31	ref 4 p 3	4-11,30	ref 4 p 30	ref 4 p 30
Circumference (m)	6695	6476	3238	3238	3238
# bunches per DR	2610	2610	1305	2610	1305
damping time ms	26	21	24	24	24
RF Voltage MV/DR	24	21	7.5	7.5	3.75
# RF cavities/DR	18	16	6	12	6
# klystrons/DR	5	4	2	4	2
Wiggler B (Tesla)	1.67	1.6	1.6	1.6	1.6
Wiggler period (m)	0.4	0.4	0.4	0.4	0.4
Wiggler lgt ea (m)	2.45	2.45	2.45	2.45	2.45
Wiggler lgt/DR (m)	200	216	78	78	78
# wigglers/DR	80	88	32	32	32



# Cost Differentials for ML

Main Linac -KCS	Full Power 2625		Reduced # 1312		cost diff - M	Notes: basis = ChrisA's cartoon 27unitKCSpowerflow.pptx
	Quantity	Cost - M	Quantity	Cost - M		
Klystrons - 10 MW	714	206.3	499	153.7	-52.6	cost includes Learning Curve
Modulators & PS	714	377.7	499	282.4	-95.3	assumes same performance
KCS Pipe - meters	1428	1.4	998	1.0	-0.4	differential in RF Building
CTO Couplers - pairs	714	7.1	499	5	-2.1	klystrons to pipe in building
W.G. Switches - pairs	714		499			safety - have no unit cost
Cryogenics Plants - MW	10*4.42	228.1	10*4.12	218.8	-9.3	same cryo accessories & distrib
CFS: Civil		609.5		593	-16.5	
CFS: Electrical - MW	151.6	142.5	119.7	125.5	-17.0	red = changed since draft
CFS: Air + Cooling - MW	79.8	117.3	63.6	107.49	-9.8	
<b>totals</b>		<b>1689.9</b>		<b>1486.9</b>	<b>-203.0</b>	

Main Linac - DRFS <b>modified 18jan2011</b>	Full Power 2625		Reduced # 1312		cost diff - M	Notes:
	Quantity	Cost - M	Quantity	Cost - M		
Klystrons - 800 KW	7592	493.5	3796	247.0	-246.5	includes extra capacity for Low P
Magic Tees - Hybrids	7592	52.0	11690	80.0	28.0	for DC PS and Modulators
DC PS (incl backup)	584	174.0	584	65.1	-108.9	did not include "learning curves"
MA Pulser (incl backup)	876	52.6	437	35.0	-17.6	
Cryogenics Plants - MW	10*4.42	228.1	10*4.72	237.2	9.1	same cryo accessories & distrib
CFS: Civil		632.9		632.9	0.0	
CFS: Electrical - MW	182.3	186.7	167.8	171.8	-14.9	
CFS: Air + Cooling - MW	92.8	171.1	61.3	159.1	-12.0	
<b>totals</b>		<b>1990.9</b>		<b>1628.1</b>	<b>-362.8</b>	

**tab: low-P**



# DR & Summary Cost Differentials

Damping Rings	Full Power 2625		Reduced # 1312		cost diff - M	restore 2625 bunches 1 e- & 2 e+ DRs		Notes:
	Quantity	Cost - M	Quantity	Cost - M		Quantity	Cost - M	
Technical Elements		425.8		276.3	-149.5		426.1	see DR detail sheet(s)
Cryogenic Plants - MW	2.16	19.9	0.77	9.6	-10.3	need info	need info	two cryo plants
Cryogenic Distribution		8.5		8.3	-0.2		12.8	50% more for 3 rings
CFS: Civil	6.4 @ 5	127.8	3.2 @ 7.5	107.3	-20.5		107.3	note 7.5 m tunnel to allow 3 rings
CFS: Electrical - MW	26.3	20.1	12.8	16.3	-3.8	19.2	18.1	
CFS: Air + Cooling - MW	19.5	32.0	8.5	24.2	-7.8	14.8	30.3	
<b>totals</b>		<b>634.1</b>		<b>442.0</b>	<b>-192.1</b>		<b>594.5</b>	

Summary (in M ILCU)	ML	DR	Total	wrt 6,618 M ILCU
Savings with KCS	-203	-192	-395	-6.0%
Savings with DRFS	-363	-192	-555	-8.4%

tab: low-P





## *restoration of 2625 bunches/train*

- KCS – relatively easy, increase size of RF building, install klystrons & modulators, on surface. Minimum impact on accelerator operations. Should install full Cryo plants from start (don't save that 9 M ILCU earlier)
- DRFS – need to add many more klystrons in tunnel, interrupting accelerator operations. Due to higher cryo load for DRFS reduced # bunches, larger plants were installed and will not need upgrading.
- Damping Ring – install a second Positron Ring, inj/extr  $e^+$  switches, and more cryo and power.



# restoring 2625 bunches/train

Main Linac -KCS	Full Power	to restore 2625		terminate	Notes
	2625	initiallly	defer	at 1312	
	Cost - M	Cost - M	Cost - M	Cost - M	
Klystrons - 10 MW	206	154	53	154	red = PHG guess
Modulators & PS	378	282	95	282	
KCS Pipe - meters	1	1	0	1	
CTO Couplers - pairs	7	5	2	5	
W.G. Switches - pairs					
Cryogenics Plants - MW	228	228	0	219	could defer some compressors
CFS: Civil	610	593	17	593	defer buildings
CFS: Electrical - MW	143	134	9	126	assume some fraction ~ 50%
CFS: Air + Cooling - MW	117	112	5	107	assume some fraction ~ 50%
<b>totals</b>	<b>1690</b>	<b>1510</b>	<b>180</b>	<b>1487</b>	

Damping Rings - 3.2 km 1 e+ & 1 e- => 2 e+ & 1 e-	Full Power	to restore 2625		terminate	Notes
	2625	initiallly	defer	at 1312	
	Cost - M	Cost - M	Cost - M	Cost - M	
Technical Elements	426	276	150	276	maybe some extra/reconfigure
Cryogenic Plants - MW	20	20		10	could defer some compressors
Cryogenic Distribution	9	8	0	8	minor # new boxes
CFS: Civil	128	107	21	107	already paid for 7.5 m tunnel
CFS: Electrical - MW	20	18	2	16	assume some fraction ~ 50%
CFS: Air + Cooling - MW	32	28	4	24	assume some fraction ~ 50%
<b>totals</b>	<b>634</b>	<b>458</b>	<b>176</b>	<b>442</b>	

sums ML (KCS) + DR	2324	1968	356	1929	
difference = extra investment cost =		1968	minus	1929	39 M ILCU (= 0.6% of 6.6 B ILCU)





## *check KSC optimization!*

Is ChrisA's optimization of KCS for reduced # bunches optimal?

He tried to minimize dynamic load on cryogenics system

What if he took DRFS approach => cut # klystrons in half which forces longer  $t_{rf}$  pulse length?

<u>Full Power</u>		<u>KCS approach</u>		<u>DRFS approach</u>	
714 klys	206 M	499 klys	194 M	357 klys	116 M
714 mod	378 M	499 mod	282 M	357 mod*	251 M
Cryo 4.42	<u>228 M</u>	cryo 4.12	<u>219 M</u>	cryo 4.72	<u>237 M</u>
Total	812 M		695 M		604 M

This used LC = 90% for klystrons, 88.5% for mods

\* I did multiply by modulator cost by  $\sqrt{2.159/1.564} = 1.175$

Have not looked at cost for increased pulse length for klystron

Have not looked at Electrical & Cooling ~ 27 M less for DRFS




# Backup notes



## *errors, omissions, inconsistencies*

- CFS: no CMU fire-rated enclosure for DRs, however, this would be no differential cost  
Not needed for DR due to new understanding of fire protection reqs for single tunnels
- CFS did not vary the power requirements for Cryogenics Plants for DR (used RDR for all)
- CFS did not change capacity of DR service buildings for electrical and cooling, but did vary for cryogenics
- **CHECK THIS OUT!**





# ILC-GDE Cost Disclosure Rules

<http://www-ilcdcb.fnal.gov/cost-confidentiality-official-njw.pdf>

This meeting will involve discussion of actual cost estimating numbers and data

“review” access has been granted by the GDE Executive Committee to cost data

- questions are allowed, but

- no hard copy or e-file

you must agree (or have previously agreed) not to discuss outside of context of this meeting, publish, or post on public web-site any cost estimating information