

# The Calicoes project Calice OnlinE System



# High Performance Middleware For the Calice DAQ System



Frédéric Magniette, LLR



#### The Needs

- Acquisition Chain: dev from scratch
- Control-Command Chain (Liblda)
- Human-Machine interfaces
  - For DAQ debugging
  - For data acquisition
- Properties
  - Calice compatible (DIF-LDA-ethernet-Multiroc)
  - Highly reliable
  - Strong evolutivity (developpement phase)



# Design Concepts

#### Internal Modularity

- Functional blocks with easy communication channels (on the Unix model)
- Every block is making few but making it fast and good
- Easy evolutivity

#### Parallelism

- Massively multi-threads approach
- Pipelined treatments
- Low-latency code (no barrier)

#### External Genericity

 Connected to the outside with open formats (xml, tcp sockets)



## **Acquisition Chain**

Global BD


Skiroc

Generio

LDA/ GCC/ DIF

Raw socket

Ethernet Usb PCI(e)



building events

(de)coding ASIC signal and control

Offering various distribution mode

Checking Uncapping Reordering Tagging

Transfering from/to media

Interfacing kernel and hardware

### Low level Transfer

- Standard Ethernet driver (e1000)
- Low-level socket (SOCK\_RAW)
- Limited in rate by the SOCK\_RAW implementation
- Projects to speed up: 3 alternatives
  - Migrating DAQ to kernel compatible code (UDP)
  - Specific kernel driver for DMA transfer of actual ethernet format
  - Specific ethernet adapter (ODR?)




# LDA/GCC/DIF Uncap




- One of the two specific parts of the system (dependant of the DIF Firmware version)
- Very basic : uncap, DIF tagging
- Projects
  - Control improvement: integrity control (CRC), packet loss control and measurement, reordering
  - Implementation of local-id for multi-LDA support

#### The distribution bus

- Split data into beams (by dif)
- Offer the maximum flexibility in data treatment
  - Offline through files
  - Remote online through sockets
  - High performance online through Shared Memory
- Pipelined treatments for maximizing the flow rate




# Signal Uncap



- The second specific block of the system (dependant on the roc chip version)
- Actually adapted for skiroc, can be ported easily to spiroc
- Uncaps the skiroc data to produce isolated physical events
- Computes real-time statistics

# Online Event building


- Not implemented now
- Basic idea : change the multiplexing from location to time
- Massively multi-thread for handling the data rate
- Project
  - defining a good pivot format (as it exists in DH-CAL)
  - Interfacing Marlin processor with uncap threads through TCP sockets



### The Control-Command Chain

SI-W ECAL actual hardware






- All this stuff is controled by specific little drivers (python and C), shell scripts and the libLDA
- All accessible through a command module via a TCP socket with xml commands

# Local Supervisor

- Local supervisor / monitor
- Allows users to send commands and read variables through the variable and command modules
- Generic design based on Gtk3/Xml description files (for high flexibility)



# Pycaldaq

Embedded Python scripts to pilot the whole detector

Program or interractive sessions


```
import caldag
def acq run():
    caldag.start acg()
    caldag.start spill()
    caldaq.start_trigger()
    time.sleep(15)
    caldaq.stop trigger()
    caldaq.stop_spill()
    caldaq.stop acq()
caldaq.stop_acq()
caldaq.stop_spill()
caldaq.stop_acq()
caldaq.flush files("trash")
for chan in range(0,64):
    caldag.system("hack_config/set_trigchan config/calib_base.txt 4 \
                                               %d config/calib/calib chan%d.txt" % (chan,chan))
    for trig in range(150,401):
         caldaq.system("hack_config/set_gtrigger config/calib/calib_chan%d.txt 4 \
                                               %d config/calib/calib_chan%d_trig%d.txt" % (chan,tr:
        caldag.send config("config/calib/calib chan%d trig%d.txt" % (chan,trig))
                                                                                             12
        acq run()
        caldag.flush files("calib chan%d trig%d" % (chan, trig))
```

#### The Framework connection

- Connection to XDAQ (or any other framework Doocs, Tango) through the TCP/XML command module
- The framework can be interfaced at any level through a generic device server configured by an xml command file
- Symmetrically, the framework can also provides devices to integrate in the control-command scheme via a specific command module

#### Statistics GUI

 Display\_stats: a tool for displaying the calibration statistics, online or offline




#### Hitcam

Online and offline visualisation of hits (internal trigge

•Plugged via tcp socket to the a

- Adjustable gain
- Video generation
- •Allows to proceed to :
- beam spotting
- online visual data control
- beam supervision



#### Results

- Good data rate: perfect for 10 Hz Spill
- Very good reliability
  - 15 days of beamtest at DESY without bugs
  - 3 weeks of calibration without a problem (20480 configurations loaded, 122880 data files)
- Easy to use
  - Multiples graphical interfaces
  - Programming interface
- Good evolutivity
  - Any block can be improved and modified easily by anybody (especially python command modules)
  - Easy to adapt to another setup : AH-Cal collaboration

# Perspectives



- Increasing the flow rate by specific soft or hard modification
- Migrating the control-command to unified Tcp/Xml system
- Additionnal online monitoring (data quality, calibration...)
- Aggregating the signal events in an event-builder
- Integrating the system in the XDAQ framework
- Handling global configuration files through the unified control-command system



# Thank you for your attention, any questions?