
Site-specific CF design from TDR


LCWS13, 12 November 2013


Atsushi ENOMOTO (KEK)

LCWS13 Tokyo University









General Technical Issues

after bedrock geological feature confirmed

Optimization of structure cross section concerning necessary rock support vs. costs.

- (1) Chose rock support system: sprayed concrete, rock balts, PS anchor
- (2) Optimize sizes and cross sections for various caverns
- (3) Evacuation of inflow waters

Tunnel Design (Typical cross section)


- Distributed Klystron System (DKS)
 - RDR-like Main Linac (ML) Tunnel Design
 - with "beam" and "service" tunnels and
 - <5 km access intervals due to limited 2K-He transfer length.</p>

ML tunnel

* Shield wall

- thickness, material density, construction methods (precast, in-situ, prepacked)


* Precise shape of "Kamaboko" and other structures



Remaining Tunnel Designs for Major Technical Area (In Asian Region)





Main Linac Length




Detector Hall









Detector Hall tunnel

11.0m

4.0m 1.0m


25.0m

(SECTION A-A)

- * Section and support
- * Inner structure Crane support
- * Construction procedure including associated small caverns and tunnels * Transportation during construction

Access Hall

He Compressor, Cryogenic Facilities, Electrical Substation, Cooling-Water System, Plumbing System




Detector Hall tunnel

- * Layout and Structures for service
- A equipment
 - * Access and transport for Machine
 - * Shielding
 - * Doors
 - * Crane
 - * Inflow water
 - * Section shape and Rock support

Access Tunnel

slope of <10% (ML & DR), <7% (DH)





Surface Structures


Our	1400	_	Juar	_	<u>ui co</u>			\vdash	Number of	ildin		04		-								
								⊢	buildings	_	_		_	4								
					-				Floor Area (m2)		91,	27	5									
PM-13	PM-12		PM-10		PM-8		DR	⊢	PN		Exp.	Gen	(total)	DR		PM+8		PM+10		PM+12		PM+13
0	3,450		4,250		4,300		0		68,9					0		3,475	1	3,450		3,450		0
Number of buildings Area (foor)	Number of buildings Area (floor)	10	Number of building	1 4 199	Number of buildings Area Hoori 4	13	Number of buildings Area (foor)	0	Number of buildings Area floor)	10.0	14.0	45.5		t Number of buildings 6 Area (floor)	1	Number of buildings Area (foor) 2	11	Number of buildings Area (floor)	10	Number of buildings Area floor	10	Number of buildings 0 Area (foor) 0
Office for Technical Staff	Office for Technical Staff	1 200	Office for Technical Staff	1 200	Office for Technical Staff	1 200	Office for Technical Staff	1	Main Building (Office)		_	1		Office for Technical Stat	_	Office for Technical Staff	1	Office for Technical Staff	1 200	Office for Technical Staff	1 290	Office for Technical Staff
Electric Building	Electric Building	1	Electric Building	1	Electric Building	1	Electric Building	-	Detector Assembly		2 12,000		2	Electric Building		Electric Building	1	Electric Building	1	Electric Building	1 190	Electric Building
Cooling Tower & Pump Station	tooling Tower & Pump Statio	1 650	looiing Tower & Pump Stati	0 1 650		1 650	looling Tower & Pump Statio		Survice Building				1 14,000				1 10	oling Tower & Pump Statio	1 650	looling Tower & Pump Statio	1 650	icoling Tower & Pump Statio
Cooling Ventilation Building	Cooling Ventilation Building	1 400	Cooling Ventilation Building	400	Cooling Ventilation Building	1 400	Cooling Ventilation Building		Office for technical Staff		1 2,600		1 3,800	Cooling Ventilation Building	1	Cooling Ventilation Building	1 0	ooling Ventilation Building	1 400	Cooling Ventilation Building	1 400	Cooling Ventilation Building
Cryo-Warm Compressor	Cryo-Warm Compressor		Cryo-Warm Compressor		Cryo-Warm Compressor		Cryo-Warm Compressor		Office for technical Staff	1 200			200	Cryo-Warm Compressor		Cryo-Warm Compressor		Cryo-Warm Compressor		Cryo-Warm Compressor		Cryo-Warm Compressor
Cryo- Surface Cold Box	Cryo- Surface Cold Box		Cryo- Surface Cold Box		Cryo-Surface Cold Box	_	Cryo-Surface Cold Box		Electric Building		1 900		400	Cryo-Surface Cold Box		Cryo-Burface Cold Box		Cryo-Surface Cold Box		Cryo-Surface Cold Box		Cryo-Surface Cold Box
Control Rooms		100	Control Rooms	1		1 100	Control Rooms		Electrical Transformer	_		1 10,00	10,000				1	Control Rooms	1	Control Rooma	1 190	Control Rooms
Workshop		1 450	Workshop	1 450		1 450	Workshop	60	coling Tower & Pump Station	1 660	1 650		1,300	Workshop			1	Workshop	1 450	Workshop	1 450	Workshop
Site Access Building	Site Access Building	1 100	Site Access Building	1		1	Site Access Building	•		1 400	1 400		2 900	Site Access Building			1	Site Access Building	1	Site Access Building	1 100	Site Access Building
Shaft Access		1 300		1 300	Shaft Access	1 500	Shaft Access	D		1 300	1 500		2 600			Shaft Access 5	1		1 900	Shaft Access	1 500	Shaft Access
Underground Galieries Services	Underground Galleries Services	1 150		1		1	Underground Galieries Services		Main Heat Plant			0		Underground Galleries Services		Services 1	1	Underground Gallertes Services	1	Underground Galleries Services	1 150	Underground Galleries Services
He Tank Platform	He Tank Platform	1,000	Rediation Building	1 900		1 890	He Tank Platform		Computer center	_			1,200			Caller Building 1	1	He Tank Platform	1	He Tank Platform	1,000	He Tank Platform
			He Tank Platform	1,000	Laser Building	2 50		lars	age for Vehicules Maintenanc			1,000	1 1,000				1					
						1			Cryo-Warm Compressor				0	-								
									Cryo-Surface Cold Box				0	-								
									Control Room			1,000	1,000									
									Control Rooms	1	1 100		2									
								Γ			1 450		2 900			- 10072						
									Site Access Building	1 100	1 100		2			Facilities:						
								Γ		1 500	1 300		2			facilities for gr						
									Survey Gallery			1 900	1 900			pe and quantitie e facilities mov					N e	stimates)
									Survey Calibration (piles)			1	1			development c		-				
									Underground Galleries Services	1 180	1		2		lei	development c	05	is are based	01	aleas		
									Safety Buildings			1	1									
									Gaz Buildings	_	1 400		1 400	SO		RCE AREA		QTY	AF	-	% A	
									He Tank Platform	1	1		2	e- Sourc e+ Sourc				0		0	0.	
									Reception	_		1	1	Damping		ng		0		0	0.	0%
								w	harehouse / Goods reception	_		1		RTML			_	0	_	0	0.	
									Restaurant & Cafeteria	_		1	1 1,200	Main Lina BDS	ac		_	65 10		22,375 3,650	24	
									Hosteis	_		1	1 2,200	IR				28		65,250	71	.5%
									I					+		TOTAL		103	1	91,275	100	0.0%

ILC Surface Buildings (TDR)



Electric Distribution

Existing power line available in both sites, by Tohoku Electric Power Co. and Kyushu Electric Power Co. High voltage, assumed to be 275 kV in TDR Asian site, depends on the site location.



Power Loads Klystron Surface (clustered) Power loads for DKS MLs and CFs Underground Waveguides TDR baseline (half beam power operation) $(100 \sim 1200 \text{ m})$ **Klystron** different (distributed) **Confirm power loads RF** units **RF** units * Response for machine design same (cryomodules) (cryomodules) developments DKS KCS * Site-specific conventional power **Klystron** 378 403 - Temp, humid, access length, ... **RF** units 567 567 ~6% DKS Power Load in MW (TDR baseline - Low Power) Conventional NC Area System RF Power Racks Cryo Total magnets Normal Emerg 1.28 0.09 0.73 0.80 1.47 0.50 4.87 e- sources 1.39 0.09 4.94 0.59 1.83 9.32 0.48 e+ sources 8.67 2.971.45 1.93 0.70 15.72 DR RTML 4.76 0.32 1.26 1.19 0.87 8.40 part of ML cryo Main Linac 52.13 4.66 0.91 32.00 12.10 4.30 106.10 BDS 10.43 041 1.34 0.20 12.38 1.21 1.21 Dumps 0.00IR 5.67 1.16 2.650.900.96TOTALS 68.2 5.2 22.437.920.8 9.2 164


(Americas) 74.2 MW

14.6 MW 6.4 MW 161 MW



High-Voltage Distribution

275-kV Main Substation and 66-kV distribution






High-Voltage Distribution (2)

Access-Hall 66-kV Substations and 6.6-kV distribution

table:overall electrical load summary

	distribution	Power(MVA)	PM-13	PM-12	PM-10	PM-8	PM-AB, PX	PM+8	PM+10	PM+12	PM+13	тот	ΓAL
TOTAL	А	135.54		22.34	18.31	21.43	16.97	15.85	18.31	22.34		62.08	73.47
TOTAL	В	103.54		15.89	13.98	19.85	11.56	12.40	13.98	15.89		49.72	53.83

66kV/6.6kV transformer		30MVA 30 30MVA 30			-	30MVA 30MVA	-	
------------------------	--	----------------------	--	--	---	----------------	---	--






Mechanical System

						Confirm Cooling Requirements
	Heat loads	Water	Chilled wate	Air	Chilled Air	
Surface	conventional	use		use		* Water and room temperature,
Tunnel	technical	use	use		use	stabilities
	conventional (electrica				use	Stabilities
	conventional (mechan	use		use		Remaining design area
						and the second se
<35	deg C water is prov	vided evo	ent hot su	mmer d	avs	* Sources, RTML, BDS, DH
-00	deg o water is prov	ided ext	ept not su	inner u	ays	
		and so the				20.1 MW 21.1 MW
Sunda	ace Structures				e e	15.8 MW
Surra	ace structures					
To-with					CT-ab	CT+8 Mechanical ation
	Dentro I. States	-		21.1 M		25.2 MW Mechanical Station
		20.1 MW	- Horaco			Mechanical
	-unface road		The Martin	-	Constant March	CT-8 Mechanical Station
Exis	ting surface (CT-	12	The second second	СТ-10 🕽		Station 21.9 MW
	PM-13			Section 200	Mech	hanical
					Sta	tion 0°
Section 2	Access Tu		echanical	Access I	Hall	2.5 km (CT-X
	(Slope	and the second second	Station		2.5 k	(m
	Colone -	TOVO	12	2.5 km		
	1			2.3 MI		- icting roa
					1000	EXISTING
	2.5	cm				and the second
. /					A CALCON	A MARTINE AND A
				The state of the s	1	and a second and a s
					(The b	actground photo shows a similar site image but does not show the real site.
	A LOCAL DESIGNATION OF THE OWNER	and the second	and show the	14 3AH7	Total State	


Heat Loads • Heat loads for DKS M <u>DKS</u> Thermal Loads in MW (T	Confirm heat loads * Response for machine design developments * Site-specific conventional power - Temp, humid, access length,					
Area System	load to LCW	load to Air	Conven tional	Cryo (Water load)	Total	
e- sources	1.40	0.70	1.87	0.80	4.77	
e+ sources	5.82	0.64	2.27	0.59	9.32	
DR	10.92	0.73	2.69	1.45	15.79	
RTML	4.16	0.76	2.02	part of ML cryo	6.94	
Main Linac	42.17	5.57	16.89	32.00	96.63	
BDS	9.20	1.23	1.68	0.41	12.52	
Dumps	14.00		1.12		15.12	
IR	0.40	0.76	1.79	2.65	5.60	
TOTALS	88.1	10.4	30.3	37.9	167	
	(A	mericas)	13.5 MW		154 MW	

Process Cooling Water Surface layout Heat loads for DKS-MLs and Site-specific Conventional system Utilizing Design not done for the central region, roughly cost-estimated . heated water COOLING TOWERS 5 MW x (n + 1) \sim $>\sim$ \sim ~ ~ ~ ~ ~~~~ ~ ~ ~ ~ ~ ~ ~ ~ ~~~~ 0150 kW 🖄 150 kW 0150 kW 🖄 150 kW **⊘**150 kW **⊘150 kW** SURFACE \sum _31C 1st LOOP 42CÎ Layout, support method and schedule Layout and HEAT EXCHANGERS 2nd LOOP (Process Water) 5000 5 MW x (n + 1) installation of 400¢ \rightarrow 🖉 180 kW 32C mechanical DEIONIZATION FILTER HEAT equipment 180 kW EXCHANGERS DEAERATOR 388.7 kW 11 kW 3rd LOOP (LCW) 80¢ 180 kW Lðá 22 34C CRYO 11 kW WARM 1.5 kW RF RF RF RF 180 kW COMPR EXPANSION TANK LCW SKIDS x 31 < 180 kW 45C EXPANSION TANK 180 kW (43C




Piped Utilities

- Inflow ground water assumed 1 ton/km/min., Utilization of inflow water for cooling
- Treatment of leakage water from accelerator, Underground access hall utilities
- Design not done for the central region, roughly cost-estimated.



Chilled Water


- Heat loads for DKS-MLs and Site-specific Conventional system
- Design not done for the central region, roughly cost-estimated




<u>Safety</u>

Evacuation Plan


- In the case which the fire started in the service tunnel, we can take refuge in the Beam-tunnel.
- Evacuation in two directions is attained.







Construction Schedule



LCWS13 Tokyo University

Asian region CFS Design Summary

- Site investigation is ongoing in two candidate sites
- Tunnel design was progressed using NATM
- Large cavern designs were made (DH, AH)
- Electrical and mechanical systems were developed for ML
- Construction schedule and costs were studied